

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Jackson**
 Month/Year: **Jul-23**

System Name: Hiland WC - Shady Cove		ID#: 41 01520		WTP : TP - A2(Seccua)			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
7/1/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/2/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/3/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/4/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/5/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/6/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/7/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/8/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/9/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/10/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/11/2024	0.01	0.01	0.01	0.01	0.01	0.00	0.01
7/12/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/13/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/14/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/15/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/16/2024	0.00	0.01	0.01	0.01	0.01	0.01	0.01
7/17/2024	0.01	0.01	0.01	0.01	0.00	0.01	0.01
7/18/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/19/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/20/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/21/2024	0.01	0.01	0.00	0.00	0.01	0.01	0.01
7/22/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/23/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/24/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/25/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/26/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/27/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/28/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/29/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7/30/2024	0.01	0.01	0.01	0.01	0.01	0.00	0.01
7/31/2024	0.01	0.01	0.01	0.01	0.01	0.00	0.01

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No	Monthly Summary (Answer Yes or No) CT's met everyday? (see <input checked="" type="radio"/> Yes / <input type="radio"/> No) All Cl2 residual at entry point <input checked="" type="radio"/> Yes <input type="radio"/> No
---	---

Notes:	PRINTED NAME: JJ Olson
	SIGNATURE: <i>JJ Olson</i>
	PHONE #: (503) 554-8333
	DATE: 08/10/24
	T-766039

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Services - Surface Water Quality Data Form				WTP- : A2		
System Name: Hiland WC - Shady Cove			ID#: 41 01520		Month/Year: Jul-23	
				Disinfection Giardia Log		
				Inactive: 1.0		

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
7/1/2024	1.50	75	112.5	12.9	7.31	37.2	Yes	120
7/2/2024	0.96	75	72.0	13.0	7.26	34.0	Yes	120
7/3/2024	0.94	75	70.5	12.6	7.28	35.3	Yes	120
7/4/2024	1.38	75	103.5	14.0	7.23	33.1	Yes	120
7/5/2024	1.17	75	87.8	12.4	7.31	37.6	Yes	120
7/6/2024	1.11	75	82.9	11.9	7.33	38.8	Yes	120
7/7/2024	0.99	75	74.3	11.2	7.29	39.3	Yes	120
7/8/2024	0.93	75	70.1	11.9	7.26	37.0	Yes	120
7/9/2024	1.47	75	110.0	13.2	7.36	37.0	Yes	120
7/10/2024	1.88	75	141.0	13.6	7.37	38.0	Yes	120
7/11/2024	0.98	75	73.5	12.8	7.30	35.1	Yes	120
7/12/2024	1.07	75	80.3	12.1	7.26	37.2	Yes	120
7/13/2024	0.96	75	72.0	12.5	7.29	35.6	Yes	120
7/14/2024	1.11	75	83.3	14.0	7.36	33.8	Yes	120
7/15/2024	1.43	75	107.3	12.1	7.28	39.0	Yes	120
7/16/2024	0.95	75	71.3	12.8	7.33	35.4	Yes	120
7/17/2024	1.11	75	83.3	12.6	7.29	36.0	Yes	120
7/18/2024	1.13	75	84.8	14.0	7.30	33.0	Yes	120
7/19/2024	0.93	75	69.8	13.2	7.31	34.3	Yes	120
7/20/2024	1.47	75	110.3	13.0	7.21	35.5	Yes	120
7/21/2024	0.89	75	66.5	15.2	7.36	30.3	Yes	120
7/22/2024	1.12	75	84.0	14.4	7.31	32.2	Yes	120
7/23/2024	1.08	75	81.0	14.2	7.31	32.5	Yes	120
7/24/2024	1.16	75	87.0	12.2	7.27	37.4	Yes	120
7/25/2024	1.22	75	91.5	14.1	7.31	33.3	Yes	120
7/26/2024	1.01	75	75.8	13.3	7.26	33.6	Yes	120
7/27/2024	1.50	75	112.5	13.5	7.31	35.9	Yes	120
7/28/2024	1.06	75	79.5	14.1	7.28	32.4	Yes	120
7/29/2024	1.35	75	101.3	13.6	7.36	35.5	Yes	120
7/30/2024	0.93	75	69.6	14.0	7.34	32.7	Yes	120
7/31/2024	1.00	75	75.0	14.3	7.29	31.7	Yes	120

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350