

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Jackson**
 Month/Year: **Sep-24**

System Name: Hiland WC - Shady Cove		ID#: 41 01520		WTP : TP - A2(Seccua)			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
9/1/2024	OFF	OFF	OFF	OFF	OFF	OFF	0.00
9/2/2024	OFF	OFF	OFF	OFF	OFF	OFF	0.00
9/3/2024	OFF	OFF	OFF	OFF	OFF	OFF	0.00
9/4/2024	OFF	OFF	OFF	OFF	OFF	OFF	0.00
9/5/2024	OFF	OFF	OFF	OFF	OFF	OFF	0.00
9/6/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/7/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/8/2024	0.01	0.01	0.01	0.01	0.00	0.01	0.01
9/9/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/10/2024	0.01	0.01	0.00	0.01	0.01	0.01	0.01
9/11/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/12/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/13/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/14/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/15/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/16/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/17/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/18/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/19/2024	0.01	0.01	0.01	0.01	0.01	0.00	0.01
9/20/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/21/2024	0.01	0.01	0.01	0.00	0.01	0.01	0.01
9/22/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/23/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/24/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/25/2024	0.00	0.01	0.01	0.01	0.01	0.01	0.01
9/26/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/27/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/28/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/29/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/30/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No	Monthly Summary (Answer Yes or No) CT's met everyday? (see <input checked="" type="radio"/> Yes / <input type="radio"/> No) All Cl2 residual at entry point <input checked="" type="radio"/> Yes / <input type="radio"/> No
---	---

Notes: System offline - River pump burnt up, BWN sent to state, back in water 9/5.	PRINTED NAME: JJ Olson	
	SIGNATURE: <i>JJ Olson</i>	DATE: 10/10/24
	PHONE #: (503) 564-8333	T-766039

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Services - Surface Water Quality Data Form				WTP- : A2	
System Name: Hiland WC - Shady Cove		ID#: 41 01520		Month/Year: Sep-24	
				Disinfection Giardia Log	
				Inactive: 1.0	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
9/1/2024	OFF							
9/2/2024	OFF							
9/3/2024	OFF							
9/4/2024	OFF							
9/5/2024	OFF							
9/6/2024	1.55	75	116.6	13.3	7.33	36.7	Yes	120
9/7/2024	1.53	75	114.8	13.6	7.36	36.4	Yes	120
9/8/2024	1.70	75	127.8	13.4	7.34	37.3	Yes	120
9/9/2024	1.70	75	127.4	13.6	7.31	36.3	Yes	120
9/10/2024	1.67	75	125.3	13.6	7.35	36.8	Yes	120
9/11/2024	1.66	75	124.2	14.6	7.35	34.3	Yes	120
9/12/2024	1.53	75	115.0	14.0	7.31	34.7	Yes	120
9/13/2024	1.44	75	107.9	12.8	7.38	38.2	Yes	120
9/14/2024	1.39	75	104.3	13.5	7.31	35.2	Yes	120
9/15/2024	1.38	75	103.3	13.8	7.28	34.1	Yes	120
9/16/2024	1.52	75	114.0	11.7	7.31	40.7	Yes	120
9/17/2024	1.09	75	81.8	16.9	7.31	27.2	Yes	120
9/18/2024	1.04	75	77.6	13.4	7.28	33.8	Yes	120
9/19/2024	1.17	75	87.8	13.4	7.36	35.3	Yes	120
9/20/2024	1.25	75	93.8	12.9	7.33	36.5	Yes	120
9/21/2024	1.00	75	75.0	13.0	7.31	35.0	Yes	120
9/22/2024	0.89	75	66.8	13.0	7.29	34.3	Yes	120
9/23/2024	1.19	75	89.0	12.6	7.37	37.4	Yes	120
9/24/2024	1.25	75	94.1	13.1	7.33	36.0	Yes	120
9/25/2024	1.36	75	101.8	13.4	7.29	35.2	Yes	120
9/26/2024	1.43	75	107.3	14.0	7.30	34.2	Yes	120
9/27/2024	1.38	75	103.6	14.0	7.30	34.0	Yes	120
9/28/2024	1.32	75	99.2	13.5	7.29	34.8	Yes	120
9/29/2024	1.40	75	105.2	12.7	7.33	37.6	Yes	120
9/30/2024	1.39	76	105.7	14.0	7.31	34.1	Yes	121

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350