

OHA - DWS

Membrane Filter Monthly Operating Report

County: **Jackson**

System Name: **Shady Cove**

Month/Year: **Dec-2025**

PWS ID#: 41 - **01520**

Minimum test pressure **applied**: 22.76 psi

Plant ID: WTP - **Seccua**
(e.g., "A")

Minimum test pressure **req'd**: 22 psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR _{Max} [^{psi} /min]	LRC [log removal]	DIT Daily
4.00	4.00	

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 minutes)	Highest PDR of day [^{psi} /min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.001		0.001	>0.145		Y
2	0.001		0.001	>0.145		Y
3	0.001		0.001	>0.145		Y
4	0.001		0.001	>0.145		Y
5	0.001		0.001	>0.145		Y
6	0.001		0.001	>0.145		Y
7	0.001		0.001	>0.145		Y
8	0.001		0.001	>0.145		Y
9	0.001		0.001	>0.145		Y
10	0.001		0.001	>0.145		Y
11	0.001		0.001	>0.145		Y
12	0.001		0.001	>0.145		Y
13	0.001		0.001	>0.145		Y
14	0.001		0.001	>0.145		Y
15	0.001		0.001	>0.145		Y
16	0.001		0.001	>0.145		Y
17	0.001		0.001	>0.145		Y
18	0.001		0.001	>0.145		Y
19	0.001		0.001	>0.145		Y
20	0.001		0.001	>0.145		Y
21	0.001		0.001	>0.145		Y
22	0.001		0.001	>0.145		Y
23	0.001		0.001	>0.145		Y
24	0.001		0.001	>0.145		Y
25	0.001		0.001	>0.145		Y
26	0.001		0.001	>0.145		Y
27	0.001		0.001	>0.145		Y
28	0.001		0.001	>0.145		Y
29	0.001		0.001	>0.145		Y
30	0.001		0.001	>0.145		Y
31	0.001		0.001	>0.145		Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes		

PRINTED NAME: Curtis Olson SIGNATURE: <i>Curtis Olson</i> Notes:	DATE: 01/10/2026 WT CERT #: 216644 PHONE #: 503-554-8333
---	---

* Used for optimization purposes only.

OHA-DWS

Disinfection Monthly Operating Report

System Name: **Shady Cove**

PWS ID#: 41 - **01520**

Plant ID : WTP - **Seccua**

0.5

↩ Log
Inactivation
Required via
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) [♦] [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? [♦] [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	1.237	75	92.8	7.1	7.41	27.7	YES	120	
2	1.274	75	95.6	6.7	7.43	28.8	YES	120	
3	1.257	75	94.3	12.9	7.40	18.7	YES	120	
4	1.230	75	92.3	6.7	7.32	27.7	YES	120	
5	1.286	75	96.5	12.6	7.33	18.6	YES	120	
6	1.300	75	97.5	7.3	7.37	27.1	YES	120	
7	1.326	75	99.5	7.2	7.39	27.8	YES	120	
8	1.256	75	94.2	13.2	7.40	18.3	YES	120	
9	1.271	75	95.3	8.2	7.43	26.0	YES	120	
10	1.277	75	95.8	8.3	7.41	25.8	YES	120	
11	1.295	75	97.1	7.7	7.36	26.4	YES	120	
12	1.354	75	101.6	11.0	7.46	22.1	YES	120	
13	1.350	75	101.3	7.1	7.40	28.0	YES	120	
14	1.339	75	100.4	12.6	7.36	18.9	YES	120	
15	1.348	75	101.1	7.0	7.32	27.4	YES	120	
16	1.211	75	90.8	7.3	7.42	27.4	YES	120	
17	1.398	75	104.9	10.0	7.46	23.7	YES	120	
18	1.421	75	106.6	7.4	7.43	28.0	YES	120	
19									PLANT OFF
20	1.138	75	85.4	13.1	7.33	17.7	YES	120	
21	0.980	75	73.5	13.2	7.43	18.0	YES	120	
22	1.069	75	80.2	13.1	7.40	18.0	YES	120	
23	1.142	75	85.7	13.0	7.36	18.0	YES	120	
24	0.978	75	73.4	13.7	7.31	16.6	YES	120	
25	1.006	75	75.5	13.6	7.33	16.9	YES	120	
26	1.038	75	77.9	13.3	7.41	17.9	YES	120	
27	1.184	75	88.8	13.3	7.52	18.8	YES	120	
28	1.273	75	95.5	11.0	7.37	21.2	YES	120	
29	1.306	75	98.0	11.9	7.29	19.6	YES	120	
30	1.240	75	93.0	12.4	7.42	19.6	YES	120	
31	1.280	75	96.0	12.6	7.43	19.4	YES	120	

♦ If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350