

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Jackson**
 Month/Year: **Mar-23**

System Name: **Hiland WC - Shady Cove** ID#: **41 01520** WTP : TP - **A2(Seccua)**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
3/1/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/2/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/3/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/4/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/5/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/6/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/7/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/8/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/9/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/10/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/11/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/12/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/13/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/14/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/15/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/16/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/17/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/18/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/19/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/20/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/21/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/22/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/23/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/24/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/25/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/26/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/27/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/28/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/29/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/30/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3/31/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No	Monthly Summary (Answer Yes or No) CTS met everyday? (See back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Ciz residual at entry point > 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
---	--

Notes:

PRINTED NAME: JJ Olson

SIGNATURE: *Jeffrey Olson* **DATE:** 03/09/24

PHONE #: (503) 554-8333 **T:** 766039

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Services - Surface Water Quality Data Form				WTP - : A2	
System Name: Hiland WC - Shady Cove ID#: 41 01520 Month/Year: Mar-23				Disinfection Giardia Log Inactive: 1.0	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
3/1/2024	0.64	75	48.0	10.4	7.17	38.4	Yes	120
3/2/2024	1.32	75	99.0	9.9	7.16	42.7	Yes	120
3/3/2024	1.59	75	119.3	9.6	7.21	45.6	Yes	120
3/4/2024	1.52	75	113.6	9.1	7.24	47.1	Yes	120
3/5/2024	1.60	75	120.0	9.2	7.27	47.7	Yes	120
3/6/2024	1.57	75	117.7	8.8	7.18	47.3	Yes	120
3/7/2024	1.73	75	130.0	8.1	7.17	50.3	Yes	120
3/8/2024	1.64	75	122.7	9.8	7.18	44.6	Yes	120
3/9/2024	0.68	75	51.0	9.9	7.16	39.7	Yes	120
3/10/2024	0.65	75	48.8	7.7	7.21	46.5	Yes	120
3/11/2024	1.45	75	108.8	6.6	7.23	55.1	Yes	120
3/12/2024	1.30	75	97.7	6.1	7.16	54.6	Yes	120
3/13/2024	1.47	75	110.0	6.9	7.14	52.6	Yes	120
3/14/2024	0.99	75	74.4	6.7	7.26	52.6	Yes	120
3/15/2024	0.89	75	66.8	6.5	7.27	52.9	Yes	120
3/16/2024	1.07	75	80.5	7.2	7.33	52.5	Yes	120
3/17/2024	1.63	75	122.3	6.6	7.21	56.0	Yes	120
3/18/2024	1.09	75	81.8	7.5	7.17	48.8	Yes	120
3/19/2024	0.95	75	71.3	7.1	7.23	50.5	Yes	120
3/20/2024	0.87	75	65.3	8.3	7.24	46.3	Yes	120
3/21/2024	0.66	75	49.5	7.1	7.26	49.3	Yes	120
3/22/2024	0.97	75	72.7	7.5	7.21	48.9	Yes	120
3/23/2024	0.65	75	48.8	7.5	7.23	47.3	Yes	120
3/24/2024	1.01	75	75.8	7.7	7.19	47.9	Yes	120
3/25/2024	0.92	75	69.0	7.8	7.17	47.1	Yes	120
3/26/2024	0.90	75	67.2	7.7	7.16	46.8	Yes	120
3/27/2024	0.88	75	66.0	8.1	7.19	46.2	Yes	120
3/28/2024	0.66	75	49.5	7.6	7.26	47.7	Yes	120
3/29/2024	0.85	75	63.8	7.7	7.16	46.6	Yes	120

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350