

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Jackson**  
 Month/Year: **Nov-24**

System Name: <b>Hiland WC - Shady Cove</b>		ID#: <b>41 01520</b>		WTP : TP - <b>A2(Seccua)</b>			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
11/1/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11/2/2024	0.00	0.00	0.01	0.00	0.00	0.00	0.01
11/3/2024	0.01	0.00	0.00	0.00	0.00	0.00	0.01
11/4/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11/5/2024	0.00	0.00	0.02	0.01	0.01	0.00	0.02
11/6/2024	0.00	0.00	0.00	0.00	0.00	0.01	0.01
11/7/2024	0.00	0.00	0.00	0.01	0.01	0.00	0.01
11/8/2024	0.00	0.01	0.02	0.00	0.00	0.00	0.02
11/9/2024	0.00	0.00	0.00	0.01	0.00	0.00	0.01
11/10/2024	0.00	0.00	0.00	0.00	0.00	0.01	0.01
11/11/2024	0.01	0.03	0.18	0.14	0.09	0.01	0.18
11/12/2024	0.00	0.00	0.00	0.00	0.02	0.00	0.02
11/13/2024	0.00	0.00	0.00	0.01	0.00	0.01	0.01
11/14/2024	0.00	0.01	0.00	0.00	0.01	0.00	0.01
11/15/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11/16/2024	0.00	0.00	0.00	0.00	0.00	0.01	0.01
11/17/2024	0.00	0.00	0.02	0.00	0.02	0.00	0.02
11/18/2024	0.02	0.00	0.01	0.01	0.00	0.00	0.02
11/19/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11/20/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11/21/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11/22/2024	0.00	0.00	0.00	0.00	0.00	0.02	0.02
11/23/2024	0.00	0.00	0.01	0.00	0.00	0.00	0.01
11/24/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11/25/2024	0.00	0.00	0.01	0.02	0.00	0.00	0.02
11/26/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11/27/2024	0.02	0.01	0.00	0.00	0.00	0.00	0.02
11/28/2024	0.00	0.00	0.00	0.01	0.00	0.01	0.01
11/29/2024	0.00	0.00	0.00	0.00	0.15	0.02	0.15
11/30/2024	0.01	0.00	0.00	0.00	0.00	0.00	0.01

<p><b>Slow Sand/Membrane/DE Filtration/Unfiltered</b></p> <p>95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No</p> <p>All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No</p> <p>All turbidity readings &lt; IFE<sup>2</sup> triggers <input checked="" type="radio"/> Yes <input type="radio"/> No</p>	<p><b>Monthly Summary (Answer Yes or No)</b></p> <p>CT's met everyday? (see <input type="radio"/> Yes / <input type="radio"/> No)   All Cl2 residual at entry point <input checked="" type="radio"/> Yes <input type="radio"/> No</p>
<p><b>Notes: System offline - River pump burnt up, BWN sent to state, back in water 9/5.</b></p>	<p><b>PRINTED NAME: JJ Olson</b></p> <p><b>SIGNATURE:</b> <i>Jeffrey Olson</i>   <b>DATE: 12/10/24</b></p> <p><b>PHONE #: (503) 554-8333</b>   <b>T-766039</b></p>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

<b>OHA - Drinking Water Services - Surface Water Quality Data Form</b>				WTP- : <b>A2</b>	
System Name: Hiland WC - Shady Cove      ID#: 41 01520      Month/Year: Nov-23				Disinfection <b>Giardia Log</b> Inactive: 1.0	

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
11/1/2024	0.99	75	74.3	7.1	7.31	52.2	Yes	120
11/2/2024	1.11	75	83.5	7.5	7.30	51.4	Yes	120
11/3/2024	1.10	75	82.3	7.8	7.29	49.9	Yes	120
11/4/2024	1.05	75	78.8	7.3	7.27	50.9	Yes	120
11/5/2024	1.25	75	93.8	7.3	7.28	52.5	Yes	120
11/6/2024	1.12	75	84.0	7.7	7.26	50.0	Yes	120
11/7/2024	0.99	75	74.3	7.4	7.36	52.0	Yes	120
11/8/2024	0.85	75	63.8	7.4	7.24	49.1	Yes	120
11/9/2024	0.83	75	62.3	6.6	7.21	51.2	Yes	120
11/10/2024	0.77	75	57.8	6.9	7.27	50.6	Yes	120
11/11/2024	0.90	75	67.5	7.0	7.29	51.6	Yes	120
11/12/2024	0.77	75	57.8	6.9	7.21	49.5	Yes	120
11/13/2024	0.86	75	64.5	7.4	7.19	48.2	Yes	120
11/14/2024	1.11	75	83.4	7.4	7.22	50.1	Yes	120
11/15/2024	1.13	75	85.0	7.3	7.24	51.1	Yes	120
11/16/2024	1.52	75	114.0	7.8	7.28	52.1	Yes	120
11/17/2024	1.33	75	99.8	6.7	7.31	55.8	Yes	120
11/18/2024	1.52	75	114.3	7.1	7.24	54.1	Yes	120
11/19/2024	1.17	75	87.8	7.4	7.21	50.3	Yes	120
11/20/2024	1.25	75	93.8	7.2	7.19	51.1	Yes	120
11/21/2024	1.00	75	75.0	7.6	7.17	48.1	Yes	120
11/22/2024	1.67	75	125.0	8.0	7.24	51.8	Yes	120
11/23/2024	1.45	75	109.1	8.0	7.29	51.3	Yes	120
11/24/2024	1.18	75	88.6	7.9	7.31	50.3	Yes	120
11/25/2024	1.00	75	74.6	7.8	7.21	47.9	Yes	120
11/26/2024	0.97	75	73.1	7.8	7.21	47.8	Yes	120
11/27/2024	0.94	75	70.6	6.8	7.19	50.7	Yes	120
11/28/2024	0.93	75	69.5	6.6	7.17	50.7	Yes	120
11/29/2024	1.00	75	75.2	6.5	7.16	51.4	Yes	120
11/30/2024	1.06	76	80.6	6.7	7.17	51.4	Yes	121

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

**Return by 10th of following month by email, fax, or mail to:**  
dwp.dmnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350