

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Jackson**  
 Month/Year: **Dec-24**

System Name: <b>Hiland WC - Shady Cove</b>		ID#: <b>41 01520</b>		WTP : TP - <b>A2(Seccua)</b>			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
12/1/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/2/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/3/2024	0.01	0.00	0.00	0.00	0.00	0.00	0.01
12/4/2024	0.00	0.00	0.00	0.00	0.01	0.00	0.01
12/5/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/6/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/7/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/8/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/9/2024	0.01	0.00	0.00	0.01	0.00	0.00	0.01
12/10/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/11/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/12/2024	0.00	0.00	0.00	0.00	0.00	0.01	0.01
12/13/2024	0.00	0.01	0.00	0.00	0.00	0.00	0.01
12/14/2024	0.00	0.00	0.00	0.00	0.01	0.00	0.01
12/15/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/16/2024	0.01	0.00	0.00	0.00	0.00	0.00	0.01
12/17/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/18/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/19/2024	0.00	0.00	0.00	0.00	0.01	0.00	0.01
12/20/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/21/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/22/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/23/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/24/2024	0.00	0.00	0.01	0.02	0.01	0.00	0.02
12/25/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/26/2024	0.01	0.00	0.00	0.00	0.00	0.00	0.01
12/27/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/28/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/29/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12/30/2024	0.00	0.00	0.00	0.00	0.00	0.01	0.01
12/31/2024	0.00	0.00	0.00	0.00	0.00	0.00	0.00

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b> 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes <input type="radio"/> No	<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see <input checked="" type="radio"/> Yes / <input type="radio"/> No)   All Cl2 residual at entry point <input checked="" type="radio"/> Yes / <input type="radio"/> No
---	---

<b>Notes: System offline - River pump burnt up, BWN sent to state, back in water 9/5.</b>	PRINTED NAME: <b>JJ Olson</b>
	SIGNATURE: <i>JJ Olson</i>
	PHONE #: <b>(503) 554-8333</b>
	DATE: <b>1/8/2025</b> T-766039

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

<b>OHA - Drinking Water Services - Surface Water Quality Data Form</b>						WTP- : <b>A2</b>
System Name: Hiland WC - Shady Cove      ID#: 41 01520      Month/Year: Dec-24						Disinfection <i>Giardia</i> Log Inactive: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
12/1/2024	1.19	75	89.0	5.7	7.13	54.9	Yes	120
12/2/2024	1.81	75	135.8	5.8	7.14	58.9	Yes	120
12/3/2024	2.10	75	157.1	6.2	7.17	59.9	Yes	120
12/4/2024	2.24	75	167.9	5.9	7.22	63.0	Yes	120
12/5/2024	2.43	75	182.0	6.4	7.13	60.6	Yes	120
12/6/2024	2.39	75	179.0	6.2	7.12	60.6	Yes	120
12/7/2024	2.24	75	168.1	6.2	7.17	61.0	Yes	120
12/8/2024	1.80	75	135.2	6.4	7.19	57.3	Yes	120
12/9/2024	1.55	75	116.0	6.1	7.21	57.3	Yes	120
12/10/2024	1.41	75	105.9	5.6	7.22	58.7	Yes	120
12/11/2024	1.37	75	103.1	6.0	7.12	54.9	Yes	120
12/12/2024	1.36	75	102.2	5.9	7.13	55.1	Yes	120
12/13/2024	1.38	75	103.3	5.8	7.12	55.4	Yes	120
12/14/2024	1.40	75	105.0	6.0	7.15	55.5	Yes	120
12/15/2024	1.39	75	104.5	6.2	7.14	54.6	Yes	120
12/16/2024	1.35	75	101.5	6.0	7.18	55.7	Yes	120
12/17/2024	1.49	75	112.0	6.4	7.14	54.5	Yes	120
12/18/2024	1.62	75	121.3	6.6	7.12	54.0	Yes	120
12/19/2024	1.68	75	126.0	6.9	7.11	53.3	Yes	120
12/20/2024	1.69	75	126.6	8.6	7.17	48.4	Yes	120
12/21/2024	1.70	75	127.2	6.1	7.16	57.3	Yes	120
12/22/2024	1.93	75	144.7	6.4	7.15	57.3	Yes	120
12/23/2024	1.86	75	139.4	6.8	7.29	58.5	Yes	120
12/24/2024	1.68	75	126.2	7.4	7.27	54.5	Yes	120
12/25/2024	1.34	75	100.4	7.1	7.28	53.7	Yes	120
12/26/2024	1.22	75	91.1	7.0	7.32	53.9	Yes	120
12/27/2024	1.27	75	95.2	7.2	7.30	53.2	Yes	120
12/28/2024	1.32	75	98.6	7.3	7.27	52.4	Yes	120
12/29/2024	0.66	75	49.7	8.2	7.31	46.7	Yes	120
12/30/2024	1.15	76	87.4	7.4	7.29	51.5	Yes	121
12/31/2024	1.08	77	83.1	6.9	7.33	53.6	Yes	122

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

**Return by 10th of following month by email, fax, or mail to:**  
[dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350