

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Lincoln**  
 Month/Year: **Jan-25**

**System Name:** **Shady Cove - Seccua**      **ID#: 41 01520**      **WTP : TP - Membrane**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1/1/2025	0.15	0.19	0.14	0.27	0.27	0.16	0.27
1/2/2025	0.22	0.14	0.14	0.22	0.17	0.19	0.22
1/3/2025	0.29	0.18	0.18	0.64	0.25	0.24	0.64
1/4/2025	0.15	0.23	0.20	0.58	0.15	0.11	0.58
1/5/2025	0.16	0.17	0.14	0.18	0.07	0.10	0.18
1/6/2025	0.23	0.11	0.08	0.10	0.13	0.12	0.23
1/7/2025	0.17	0.13	0.16	0.73	0.08	0.18	0.73
1/8/2025	0.15	0.20	0.18	0.17	0.16	0.24	0.24
1/9/2025	0.14	0.19	0.23	0.23	0.24	0.24	0.24
1/10/2025	0.15	0.24	0.26	0.27	0.27	0.19	0.27
1/11/2025	0.20	0.25	0.20	0.68	0.34	0.23	0.68
1/12/2025	0.18	0.26	0.11	0.16	0.22	0.28	0.28
1/13/2025	0.20	0.22	0.20	0.41	0.61	0.33	0.61
1/14/2025	0.29	0.33	0.25	0.65	0.41	0.48	0.65
1/15/2025	0.40	0.37	0.35	0.66	0.58	0.53	0.66
1/16/2025	0.43	0.29	0.24	0.38	0.37	0.18	0.43
1/17/2025	0.22	0.21	0.27	0.34	0.25	0.16	0.34
1/18/2025	0.21	0.13	0.74	1.04	0.15	0.13	1.04
1/19/2025	0.37	0.13	0.08	0.14	0.27	0.19	0.37
1/20/2025	0.33	0.10	0.13	0.48	0.23	0.10	0.48
1/21/2025	0.11	0.12	0.17	0.19	0.15	0.06	0.19
1/22/2025	0.11	0.13	0.07	0.43	0.11	0.09	0.43
1/23/2025	0.14	0.09	0.14	0.08	0.09	0.13	0.14
1/24/2025	0.14	0.14	0.15	0.17	0.08	0.08	0.17
1/25/2025	0.09	0.06	0.22	0.19	0.09	0.10	0.22
1/26/2025	0.06	0.13	0.25	0.06	0.03	0.03	0.25
1/27/2025	0.03	0.03	0.03	0.04	0.03	0.03	0.04
1/28/2025	0.03	0.03	0.03	0.03	0.03	0.03	0.03
1/29/2025	0.03	0.03	0.03	0.03	0.03	0.03	0.03
1/30/2025	0.03	0.03	0.03	0.03	0.03	0.03	0.03
1/31/2025	0.03	0.03	0.03	0.03	0.05	0.03	0.05

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b> 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> All daily turbidity readings ≤ 5 NTU?	Yes/No Yes/No	<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see back) All Cl2 residual at entry point ≤ 0.2 mg/l?	
	<input checked="" type="radio"/> Yes <input checked="" type="radio"/> No	<input checked="" type="radio"/> Yes <input checked="" type="radio"/> No	PRINTED NAME: JJ Olson SIGNATURE: <i>Jeffrey Olson</i> DATE: 02/08/25 PHONE #: 503-554-8333      CERT #: 766039
<b>Notes:</b>			

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

WTP - : **Membrane**

**Disinfection  
Giardia Log**

**System Name: Shady Cove - Seccua**

**ID#: 41 01520**

**Month/Year: Jan-25**

**Inactiv:**

**0.5**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1/1/2025	1.55	53	82.2	6.4	7.28	28.8	Yes	35
1/2/2025	1.61	53	85.1	6.8	7.26	28.1	Yes	35
1/3/2025	1.60	53	84.9	6.7	7.21	27.7	Yes	35
1/4/2025	1.60	53	84.7	7.0	7.18	26.9	Yes	35
1/5/2025	1.17	53	62.0	6.8	7.19	25.9	Yes	35
1/6/2025	0.84	53	44.5	6.8	7.16	24.7	Yes	35
1/7/2025	0.76	53	40.2	6.2	7.21	25.9	Yes	35
1/8/2025	1.37	53	72.5	6.1	7.23	28.2	Yes	35
1/9/2025	1.23	53	64.9	6.2	7.24	27.6	Yes	35
1/10/2025	0.75	53	39.9	6.1	7.16	25.7	Yes	35
1/11/2025	0.59	53	31.2	5.8	7.14	25.5	Yes	35
1/12/2025	0.52	53	27.6	5.6	7.16	25.8	Yes	35
1/13/2025	0.51	53	26.9	5.6	7.22	26.5	Yes	35
1/14/2025	0.75	53	39.6	5.5	7.23	27.4	Yes	35
1/15/2025	2.21	53	117.1	5.1	7.19	32.9	Yes	35
1/16/2025	0.68	53	36.0	5.4	7.17	26.8	Yes	35
1/17/2025	1.30	53	68.8	5.5	7.18	28.7	Yes	35
1/18/2025	0.88	53	46.5	5.1	7.17	28.0	Yes	35
1/19/2025	0.76	53	40.2	4.8	7.12	27.7	Yes	35
1/20/2025	0.58	53	30.7	4.8	7.17	27.6	Yes	35
1/21/2025	0.57	53	30.2	4.7	7.21	28.2	Yes	35
1/22/2025	0.54	53	28.7	4.4	7.21	28.6	Yes	35
1/23/2025	0.59	53	31.4	4.3	7.17	28.5	Yes	35
1/24/2025	1.42	53	75.0	4.7	7.16	30.4	Yes	35
1/25/2025	1.50	53	79.4	4.8	7.22	31.3	Yes	35
1/26/2025	2.24	53	118.7	4.5	7.12	33.5	Yes	35
1/27/2025	1.25	53	66.1	4.3	7.16	30.7	Yes	35
1/28/2025	1.04	53	55.0	4.1	7.17	30.4	Yes	35
1/29/2025	2.34	53	124.1	4.0	7.23	36.6	Yes	35
1/30/2025	1.52	53	80.3	3.8	7.20	33.2	Yes	35
1/31/2025	1.12	53	59.4	4.5	7.14	29.6	Yes	35

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013