

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Lincoln**
 Month/Year: **Feb-25**

System Name: **Shady Cove - Seccua** ID#: **41 01520** WTP : **TP - Membrane**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
2/1/2025	0.03	0.03	0.04	0.03	0.03	0.03	0.04
2/2/2025	0.05	0.03	0.05	0.15	0.03	0.05	0.15
2/3/2025	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2/4/2025	0.03	0.03	0.03	0.03	0.03	0.06	0.06
2/5/2025	0.10	0.15	0.08	0.06	0.04	0.05	0.15
2/6/2025	0.10	0.05	0.05	0.10	0.13	0.05	0.13
2/7/2025	0.07	0.10	0.06	0.18	0.06	0.05	0.18
2/8/2025	0.15	0.05	0.03	0.15	0.06	0.05	0.15
2/9/2025	0.05	0.05	0.27	0.16	0.08	0.11	0.27
2/10/2025	0.10	0.09	0.07	0.07	0.06	0.08	0.10
2/11/2025	0.05	0.05	0.05	0.08	0.06	0.04	0.08
2/12/2025	0.06	0.06	0.05	0.05	0.03	0.03	0.06
2/13/2025	0.03	0.03	0.03	0.04	0.03	0.03	0.04
2/14/2025	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2/15/2025	0.08	0.03	0.03	0.08	0.03	0.02	0.08
2/16/2025	0.03	0.04	0.03	0.05	0.03	0.03	0.05
2/17/2025	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2/18/2025	0.03	0.03	0.03	0.21	0.05	0.03	0.21
2/19/2025	0.03	0.03	0.03	0.16	0.03	0.03	0.16
2/20/2025	0.03	0.03	0.03	0.05	0.03	0.03	0.05
2/21/2025	0.03	0.03	0.02	0.03	0.03	0.03	0.03
2/22/2025	0.03	0.03	0.03	0.02	0.03	0.02	0.03
2/23/2025	0.02	0.02	0.02	0.09	0.03	0.03	0.09
2/24/2025	0.03	0.03	0.03	0.05	0.02	0.02	0.05
2/25/2025	0.02	0.02	0.03	0.03	0.02	0.03	0.03
2/26/2025	0.03	0.03	0.03	0.03	0.02	0.02	0.03
2/27/2025	0.02	0.02	0.02	0.03	0.02	0.02	0.03
2/28/2025	0.02	0.02	0.02	0.03	0.02	0.02	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes/No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes/No	Monthly Summary (Answer Yes or No) CT's met everyday? <input checked="" type="radio"/> Yes/No (see back) All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes/ No	
	Notes:	
PRINTED NAME: JJ Olson		DATE: 03/08/25
SIGNATURE: <i>Jeffrey Olson</i>		CERT #: 766039
PHONE #: 503-554-8333		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : **Membrane**
 Disinfection
Giardia Log
 Inactiv: **0.5**

System Name: **Hiland WC - Bear Creek** ID#: **41 00482** Month/Year: **Feb-25**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
2/1/2025	2.00	53	105.9	6.4	7.13	28.7	Yes	35
2/2/2025	1.84	53	97.4	6.8	4.12	10.0	Yes	35
2/3/2025	0.66	53	35.0	6.7	7.11	24.0	Yes	35
2/4/2025	0.66	53	34.8	7.0	7.18	24.1	Yes	35
2/5/2025	1.60	53	84.9	6.8	7.21	27.5	Yes	35
2/6/2025	1.74	53	92.1	6.8	7.22	28.0	Yes	35
2/7/2025	1.72	53	91.4	6.2	7.31	30.0	Yes	35
2/8/2025	0.66	53	35.0	6.1	7.19	25.6	Yes	35
2/9/2025	1.82	53	96.4	6.2	7.16	28.8	Yes	35
2/10/2025	1.84	53	97.3	6.1	7.09	28.4	Yes	35
2/11/2025	1.90	53	100.5	5.8	7.11	29.3	Yes	35
2/12/2025	1.93	53	102.3	5.6	7.13	30.1	Yes	35
2/13/2025	1.95	53	103.1	5.6	7.14	30.4	Yes	35
2/14/2025	0.66	53	34.9	5.5	7.22	27.1	Yes	35
2/15/2025	1.92	53	101.8	5.1	7.26	32.6	Yes	35
2/16/2025	1.83	53	96.9	5.4	7.19	30.8	Yes	35
2/17/2025	1.77	53	94.0	5.5	7.26	31.2	Yes	35
2/18/2025	1.70	53	90.2	5.1	7.20	31.2	Yes	35
2/19/2025	1.65	53	87.5	4.8	7.19	31.5	Yes	35
2/20/2025	1.65	53	87.2	4.8	7.18	31.3	Yes	35
2/21/2025	1.66	53	87.8	4.7	7.16	31.4	Yes	35
2/22/2025	1.75	53	92.5	4.4	7.15	32.2	Yes	35
2/23/2025	1.92	53	101.9	4.3	7.15	33.0	Yes	35
2/24/2025	2.03	53	107.5	4.7	7.16	32.7	Yes	35
2/25/2025	2.01	53	106.7	4.8	7.21	33.1	Yes	35
2/26/2025	1.97	53	104.5	4.5	7.15	32.8	Yes	35
2/27/2025	1.97	53	104.3	4.3	7.14	33.1	Yes	35
2/28/2025	1.90	53	100.6	4.1	7.23	34.4	Yes	35

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013