

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas

Conventional or Direct Filtration

System Name: LAKE OSWEGO - TIGARD WATER SUPPLY ID#: OR4101542 WTP: A Date: November/2022

DAY	12 AM NTU	4 AM NTU	8 AM NTU	Noon NTU	4 PM NTU	8 PM NTU	Max CFE Turbidity NTU
11/01/2022	plant off	plant off	0.023	0.024	0.024	0.028	0.039
11/02/2022	plant off	plant off	0.022	0.022	0.021	0.025	0.034
11/03/2022	plant off	plant off	0.022	0.022	0.024	0.022	0.036
11/04/2022	plant off	plant off	0.023	0.027	0.023	0.022	0.034
11/05/2022	plant off	plant off	plant off	0.021	0.03	0.029	0.045
11/06/2022	plant off	plant off	0.026	0.025	0.027	0.026	0.048
11/07/2022	plant off	plant off	0.026	0.026	0.024	0.034	0.037
11/08/2022	plant off	plant off	0.022	0.026	0.03	0.029	0.039
11/09/2022	plant off	plant off	0.025	0.042	0.025	0.03	0.048
11/10/2022	plant off	plant off	0.021	0.021	0.025	0.024	0.033
11/11/2022	plant off	plant off	0.021	0.028	0.024	0.026	0.043
11/12/2022	plant off	plant off	0.022	0.029	0.028	0.024	0.040
11/13/2022	plant off	plant off	0.021	0.023	0.026	0.026	0.041
11/14/2022	plant off	plant off	0.022	0.023	0.026	0.022	0.034
11/15/2022	plant off	plant off	0.021	0.031	0.029	0.027	0.036
11/16/2022	plant off	plant off	0.021	plant off	0.021	0.022	0.032
11/17/2022	plant off	plant off	0.021	0.033	0.031	0.026	0.041
11/18/2022	plant off	plant off	0.022	0.024	0.023	0.022	0.041
11/19/2022	plant off	plant off	0.021	0.031	0.03	0.026	0.042
11/20/2022	plant off	plant off	0.022	0.024	0.023	0.02	0.032
11/21/2022	plant off	plant off	0.021	0.028	0.024	0.025	0.035
11/22/2022	plant off	plant off	0.021	0.021	0.023	0.025	0.036
11/23/2022	plant off	plant off	0.022	0.022	0.024	0.022	0.032
11/24/2022	plant off	plant off	0.02	0.021	0.027	0.027	0.034
11/25/2022	plant off	plant off	0.023	0.021	0.024	0.022	0.029
11/26/2022	plant off	plant off	0.022	0.022	0.023	0.022	0.031
11/27/2022	plant off	plant off	0.022	0.021	0.022	0.021	0.034
11/28/2022	plant off	plant off	0.02	0.02	0.022	0.027	0.037
11/29/2022	plant off	plant off	0.021	0.026	0.024	0.022	0.035
11/30/2022	plant off	plant off	0.021	0.022	0.022	0.029	0.039

Conventional or Direct Filtration

95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes / No
 All the 4-hour turbidity readings < 1 NTU? Yes / No
 All Turbidity readings $<$ IFE triggers? Yes / No

Monthly Summary (answer Yes or No)

CT's met everyday? (see page 2) Yes / No
 All Cl2 residuals at POE always > 0.2 ? Yes / No

Print Name Bret Bienerth 02-Dec-22

Signature 

Phone (503) 635-0394 Cert # 08749

