

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas

Conventional or Direct Filtration

System Name: LAKE OSWEGO - TIGARD WATER SUPPLY ID#: OR4101542 WTP: A Date: September/2023

DAY	12 AM NTU	4 AM NTU	8 AM NTU	Noon NTU	4 PM NTU	8 PM NTU	Max CFE Turbidity NTU
09/01/2023	0.022	0.021	0.02	0.02	0.02	0.021	0.034
09/02/2023	0.021	0.021	0.021	0.022	0.022	0.026	0.032
09/03/2023	0.021	0.021	0.023	0.021	0.021	0.021	0.033
09/04/2023	0.022	0.021	0.021	0.021	0.02	0.021	0.033
09/05/2023	0.022	0.021	0.02	0.02	0.02	0.021	0.028
09/06/2023	0.022	0.021	0.02	0.02	0.02	0.021	0.032
09/07/2023	0.021	0.02	0.021	0.02	0.02	0.024	0.033
09/08/2023	0.02	0.021	0.021	0.021	0.02	0.02	0.033
09/09/2023	0.02	0.02	0.021	0.021	0.02	0.02	0.055
09/10/2023	0.02	plant off	0.02	0.026	0.02	0.02	0.031
09/11/2023	0.02	plant off	0.021	0.02	0.021	0.02	0.037
09/12/2023	0.022	0.02	0.02	0.024	0.022	0.021	0.033
09/13/2023	0.021	0.021	0.021	0.021	0.021	0.02	0.034
09/14/2023	0.021	0.022	0.021	0.021	0.02	0.021	0.045
09/15/2023	0.022	0.021	0.022	0.021	0.03	0.021	0.031
09/16/2023	0.021	0.021	0.022	0.021	0.021	0.021	0.034
09/17/2023	0.021	0.021	0.043	0.021	0.022	0.022	0.044
09/18/2023	0.023	plant off	0.022	0.021	0.022	0.022	0.043
09/19/2023	0.023	0.022	0.022	0.021	0.022	0.015	0.033
09/20/2023	0.021	0.022	0.023	0.022	0.022	0.022	0.034
09/21/2023	plant off	0.022	0.022	0.02	0.02	0.02	0.035
09/22/2023	0.023	plant off	0.034	0.02	0.02	0.02	0.034
09/23/2023	plant off	plant off	0.021	0.02	0.02	0.021	0.033
09/24/2023	plant off	plant off	0.023	0.021	0.023	0.021	0.033
09/25/2023	plant off	plant off	0.021	0.021	0.02	0.02	0.032
09/26/2023	plant off	plant off	0.022	0.021	0.02	0.021	0.039
09/27/2023	plant off	plant off	0.021	0.021	0.021	0.022	0.034
09/28/2023	plant off	plant off	0.023	0.022	0.021	0.021	0.048
09/29/2023	plant off	plant off	0.024	0.021	0.021	0.021	0.035
09/30/2023	plant off	plant off	0.036	0.021	0.02	0.02	0.044

Conventional or Direct Filtration

95% of the 4-hour turbidity readings <=0.3 NTU? Yes / No
 All the 4-hour turbidity readings < 1 NTU? Yes / No
 All Turbidity readings < IFE triggers? Yes / No

Monthly Summary (answer Yes or No)

CT's met everyday? (see page 2) Yes / No
 All Cl2 residuals at POE always > 0.2? Yes / No

Print Name Bret Bienerth 02-Oct-23

Signature 

Phone (503) 635-0394

Cert # 08749

