

OHA - Drinking Water Services - Surface Water Quality Data Form

County:

Lane


Cartridge or Bag Filtration

Month/Year:

25-Mar

System Name:		Fern Acres		ID#:	41	01563	WTP ID:	TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]		
1	18.00	2.00	16.00	45.00	0.43	0.43		
2	0.00	2.00	0.00	45.00	0.43	0.43		
3	0.00	2.00	0.00	45.00	0.44	0.44		
4	18.00	2.00	16.00	45.00	0.44	0.44		
5	0.00	2.00	0.00	45.00	0.48	0.48		
6	0.00	2.00	0.00	45.00	0.44	0.44		
7	19.00	2.00	17.00	45.00	0.49	0.49		
8	18.00	2.00	16.00	45.00	0.48	0.48		
9	0.00	2.00	0.00	45.00	0.48	0.48		
10	0.00	2.00	0.00	45.00	0.45	0.45		
11	0.00	2.00	0.00	45.00	0.45	0.45		
12	18.00	2.00	16.00	45.00	0.42	0.42		
13	0.00	2.00	0.00	45.00	0.44	0.44		
14	0.00	2.00	0.00	45.00	0.47	0.47		
15	18.00	2.00	16.00	45.00	0.51	0.51		
16	0.00	2.00	0.00	45.00	0.45	0.45		
17	0.00	2.00	0.00	45.00	0.44	0.44		
18	20.00	2.00	18.00	45.00	0.42	0.42		
19	0.00	2.00	0.00	45.00	0.46	0.46		
20	20.00	2.00	18.00	45.00	0.49	0.49		
21	0.00	2.00	0.00	45.00	0.51	0.51		
22	0.00	2.00	0.00	45.00	0.52	0.52		
23	0.00	2.00	0.00	45.00	0.59	0.59		
24	22.00	2.00	20.00	45.00	0.49	0.49		
25	0.00	2.00	0.00	45.00	0.47	0.47		
26	22.00	2.00	20.00	45.00	0.49	0.49		
27	0.00	2.00	0.00	45.00	0.57	0.57		
28	24.00	2.00	22.00	45.00	0.74	0.74		
29	0.00	2.00	0.00	45.00	0.56	0.56		
30	0.00	2.00	0.00	45.00	0.52	0.52		
31	0.00	2.00	0.00	45.00	0.51	0.51		

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: Dan Reitz	
	SIGNATURE: 	3/31/2025
	PHONE #: (541) 342-1718	CERT #: 6528

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	Fern Acres	ID#: 41	01563	Month/Year:	Mar-25	Disinfection Giardia Log Inactiv:	1
---------------------	-------------------	----------------	--------------	--------------------	---------------	--	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.51	130	66.3	10.3	7.10	37.1	YES	18
2	0.5	130	65.0	10.6	7.03	35.5	YES	18
3	0.53	130	68.9	10.7	6.69	31.5	YES	18
4	0.51	130	66.3	9.6	7.14	39.4	YES	18
5	0.5	130	65.0	9.6	7.16	39.6	YES	18
6	0.49	130	63.7	9.3	7.12	39.8	YES	18
7	0.54	130	70.2	9.2	6.98	38.4	YES	18
8	0.59	130	76.7	10.4	6.88	34.5	YES	18
9	0.56	130	72.8	10.3	6.94	35.3	YES	18
10	0.54	130	70.2	10.5	7.01	35.6	YES	18
11	0.57	130	74.1	9.9	7.11	38.5	YES	18
12	0.56	130	72.8	9.3	7.18	40.9	YES	18
13	0.52	130	67.6	9.1	7.19	41.4	YES	18
14	0.55	130	71.5	8.9	6.94	38.6	YES	18
15	0.56	130	72.8	8.8	7.06	40.6	YES	18
16	0.57	130	74.1	8.6	7.01	40.4	YES	18
17	0.55	130	71.5	9.2	7.11	40.2	YES	18
18	0.58	130	75.4	9.4	7.09	39.5	YES	18
19	0.55	130	71.5	9.1	7.16	41.1	YES	18
20	0.58	130	75.4	9.1	7.17	41.4	YES	18
21	0.62	130	80.6	9.6	7.04	38.5	YES	18
22	0.64	130	83.2	9.7	6.91	36.7	YES	18
23	0.61	130	79.3	10.1	6.87	35.1	YES	18
24	0.64	130	83.2	9.8	6.93	36.7	YES	18
25	0.59	130	76.7	9.6	6.89	36.4	YES	18
26	0.6	130	78.0	9.5	6.95	37.5	YES	18
27	0.53	130	68.9	9.8	6.92	36.1	YES	18
28	0.64	130	83.2	9.6	6.88	36.5	YES	18
29	0.51	130	66.3	9.8	6.68	33.2	YES	18
30	0.63	130	81.9	10.3	7.54	43.8	YES	18
31	0.48	130	62.4	9.0	6.75	35.7	YES	18

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350