

OHA - Drinking Water Services - Surface Water Quality Data Form

County:

Lane

Cartridge or Bag Filtration

Month/Year:

July 2025

System Name:		Fern Acres		ID#:	41	01563	WTP ID:	TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]		
1	21.00	2.00	19.00	45.00	0.22	0.22		
2	21.00	2.00	19.00	45.00	0.21	0.21		
3	21.00	2.00	19.00	45.00	0.19	0.19		
4	21.00	2.00	19.00	45.00	0.21	0.21		
5	21.00	2.00	19.00	45.00	0.17	0.17		
6	21.00	2.00	19.00	45.00	0.19	0.19		
7	21.00	2.00	19.00	45.00	0.16	0.16		
8	21.00	2.00	19.00	45.00	0.18	0.18		
9	21.00	2.00	19.00	45.00	0.17	0.17		
10	21.00	2.00	19.00	45.00	0.15	0.15		
11	21.00	2.00	19.00	45.00	0.14	0.14		
12	21.00	2.00	19.00	45.00	0.16	0.16		
13	25.00	2.00	23.00	45.00	0.17	0.17		
14	25.00	2.00	23.00	45.00	0.16	0.16		
15	25.00	2.00	23.00	45.00	0.14	0.14		
16	25.00	2.00	23.00	45.00	0.16	0.16		
17	25.00	2.00	23.00	45.00	0.17	0.17		
18	25.00	2.00	23.00	45.00	0.19	0.19		
19	21.00	2.00	19.00	45.00	0.16	0.16		
20	20.00	2.00	18.00	45.00	0.15	0.15		
21	20.00	2.00	18.00	45.00	0.15	0.15		
22	24.00	2.00	22.00	45.00	0.16	0.16		
23	21.00	2.00	19.00	45.00	0.20	0.20		
24	20.00	2.00	18.00	45.00	0.16	0.16		
25	22.00	2.00	20.00	45.00	0.19	0.19		
26	24.00	2.00	22.00	45.00	0.19	0.19		
27	21.00	2.00	19.00	45.00	0.17	0.17		
28	22.00	2.00	20.00	45.00	0.17	0.17		
29	20.00	2.00	18.00	45.00	0.15	0.15		
30	20.00	2.00	18.00	45.00	0.14	0.14		
31	20.00	2.00	18.00	45.00	0.14	0.14		

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: Dan Reitz	
	SIGNATURE: 	8/6/2025
	PHONE #: (541) 342-1718	CERT #: 6528

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: :

System Name:	Fern Acres	ID#: 41	01563	Month/Year:	July 2025	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	------------	---------	-------	-------------	-----------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.60	130	78.0	16.6	7.40	27.1	YES	18
2	0.79	130	102.7	16.3	7.50	29.4	YES	18
3	0.77	130	100.1	17.9	7.59	27.2	YES	18
4	0.68	130	88.4	17.3	7.32	25.4	YES	18
5	0.68	130	88.4	16.8	7.35	26.5	YES	18
6	0.68	130	88.4	18.0	7.53	26.2	YES	18
7	0.72	130	93.6	17.6	7.64	28.1	YES	18
8	0.67	130	87.1	17.5	7.62	27.9	YES	18
9	0.68	130	88.4	17.8	7.65	27.7	YES	18
10	0.59	130	76.7	18.4	7.47	24.6	YES	18
11	0.61	130	79.3	17.6	7.51	26.5	YES	18
12	0.64	130	83.2	17.1	7.57	28.1	YES	18
13	0.64	130	83.2	17.9	7.56	26.5	YES	18
14	0.63	130	81.9	17.6	7.59	27.3	YES	18
15	0.68	130	88.4	16.8	7.60	29.1	YES	18
16	0.65	130	84.5	16.4	7.50	28.7	YES	18
17	0.65	130	84.5	17.7	7.62	27.5	YES	18
18	0.63	130	81.9	17.8	7.61	27.2	YES	18
19	0.65	130	84.5	17.7	7.69	28.2	YES	18
20	0.63	130	81.9	17.3	7.66	28.6	YES	18
21	0.56	130	72.8	17.9	7.52	25.9	YES	18
22	0.56	130	72.8	18.6	7.57	25.2	YES	18
23	0.61	130	79.3	18.6	7.68	26.4	YES	18
24	0.62	130	80.6	17.0	7.62	28.7	YES	18
25	0.58	130	75.4	18.3	7.60	26.0	YES	18
26	0.58	130	75.4	18.6	7.62	25.7	YES	18
27	0.62	130	80.6	18.9	7.76	26.6	YES	18
28	0.59	130	76.7	18.9	7.66	25.6	YES	18
29	0.6	130	78.0	18.4	7.64	26.3	YES	18
30	0.6	130	78.0	18.3	7.65	26.6	YES	18
31	0.59	130	76.7	18.0	7.61	26.7	YES	18

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350