

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lane

Cartridge or Bag Filtration


Month/Year: February 2026

System Name: Fern Acres ID#: 41 01563 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	31.00	2.00	29.00	45.00	0.08	0.08
2	31.00	2.00	29.00	45.00	0.08	0.08
3	32.00	2.00	30.00	45.00	0.07	0.07
4	31.00	2.00	29.00	45.00	0.08	0.08
5	30.00	2.00	28.00	45.00	0.07	0.07
6	30.00	2.00	28.00	45.00	0.06	0.06
7	29.00	2.00	27.00	45.00	0.07	0.07
8	30.00	2.00	28.00	45.00	0.12	0.12
9	30.00	2.00	28.00	45.00	0.13	0.13
10	31.00	2.00	29.00	45.00	0.13	0.13
11	31.00	2.00	29.00	45.00	0.09	0.09
12	32.00	2.00	30.00	45.00	0.08	0.08
13	31.00	2.00	29.00	45.00	0.07	0.07
14	30.00	2.00	28.00	45.00	0.06	0.06
15	30.00	2.00	28.00	45.00	0.12	0.12
16	30.00	2.00	28.00	45.00	0.13	0.13
17	28.00	2.00	26.00	45.00	0.10	0.10
18	29.00	2.00	27.00	45.00	0.12	0.12
19	30.00	2.00	28.00	45.00	0.08	0.08
20	30.00	2.00	28.00	45.00	0.08	0.08
21	29.00	2.00	27.00	45.00	0.06	0.06
22	21.00	2.00	19.00	45.00	0.11	0.11
23	30.00	2.00	28.00	45.00	0.11	0.11
24	30.00	2.00	28.00	45.00	0.16	0.16
25	31.00	2.00	29.00	45.00	0.07	0.07
26	31.00	2.00	29.00	45.00	0.10	0.10
27	30.00	2.00	28.00	45.00	0.11	0.11
28	30.00	2.00	28.00	45.00	0.14	0.14
29						
30						
31						

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Dan Reitz
 SIGNATURE:  3/6/2026
 PHONE #: (541) 342-1718 CERT #: 6528

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: :

System Name:	Fern Acres	ID#: 41	01563	Month/Year:	February 2026	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	------------	---------	-------	-------------	---------------	--	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.61	130	79.3	10.8	7.63	#VALUE!	#VALUE!	18
2	0.64	130	83.2	10.6	7.64	44.6	YES	18
3	0.59	130	76.7	10.4	7.45	42.0	YES	18
4	0.67	130	87.1	10.9	7.68	44.5	YES	18
5	0.65	130	84.5	10.7	7.61	43.9	YES	18
6	0.64	130	83.2	10.7	7.57	43.2	YES	18
7	0.69	130	89.7	11.1	7.67	43.8	YES	18
8	0.64	130	83.2	10.8	7.53	42.3	YES	18
9	0.69	130	89.7	11.1	7.70	44.3	YES	18
10	0.66	130	85.8	10.6	7.64	44.7	YES	18
11	0.87	130	113.1	9.2	7.61	49.7	YES	18
12	0.85	130	110.5	9.3	7.62	49.4	YES	18
13	0.81	130	105.3	10.0	7.62	46.9	YES	18
14	0.75	130	97.5	9.8	7.51	45.4	YES	18
15	0.65	130	84.5	9.7	7.24	41.1	YES	18
16	0.73	130	94.9	9.7	7.54	46.1	YES	18
17	0.78	130	101.4	9.0	7.70	51.4	YES	18
18	0.68	130	88.4	7.9	7.46	50.3	YES	18
19	0.71	130	92.3	6.9	7.53	55.3	YES	18
20	0.72	130	93.6	7.2	7.63	56.2	YES	18
21	0.67	130	87.1	8.1	7.56	51.3	YES	18
22	0.61	130	79.3	9.0	7.47	46.5	YES	18
23	0.62	130	80.6	9.3	7.49	46.0	YES	18
24	0.63	130	81.9	10.5	7.60	44.2	YES	18
25	0.64	130	83.2	10.3	7.63	45.3	YES	18
26	0.55	130	71.5	9.8	7.34	41.9	YES	18
27	0.61	130	79.3	9.5	7.14	40.1	YES	18
28	0.62	130	80.6	9.4	7.61	47.6	YES	18
29								
30								
31								

² If Cl₂ at entry point < 0.2 mg/l or C

Return by 10th of following month by email, fax, or mail to:

Revised November 2022

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350