

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: TILLAMOOK

Conventional or Direct Filtration

Month/Year: Sep-22

Brighton Water Co			ID#: 41	05104	WTP : TP -		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				0.25			
2				0.25			
3				0.25			
4				0.27			
5				0.25			
6				0.25			
7				0.25			
8				0.25			
9				0.23			
10				0.23			
11				0.23			
12				0.23			
13				0.22			
14				0.22			
15				0.22			
16				0.23			
17				0.25			
18				0.27			
19				0.25			
20				0.25			
21				0.25			
22				0.25			
23				0.27			
24				0.27			
25				0.27			
26				0.30			
27				0.30			
28				0.32			
29				0.32			
30				0.32			
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?		yes	yes
All turbidity readings < IFE ² triggers	yes		


Sherri Stewart	
SIGNATURE:	Oct 3 2022
503-647-6485	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	Brighton Water Co	ID#: 41	05104	Month/Year:	Sep-22	Disinfection <i>Giardia</i> Log Inactive:	1
--------------	-------------------	---------	-------	-------------	--------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT 	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.22		0.0			8.5	yes	
2	0.22		0.0			8.5	yes	
3	0.22		0.0			8.5	yes	
4	0.21		0.0			8.5	yes	
5	0.21		0.0			8.5	yes	
6	0.21		0.0			8.5	yes	
7	0.21		0.0			8.5	yes	
8	0.21		0.0			8.5	yes	
9	0.21		0.0			8.5	yes	
10	0.2		0.0			8.5	yes	
11	0.2		0.0			8.5	yes	
12	0.2		0.0			8.5	yes	
13	0.2		0.0			8.5	yes	
14	0.2		0.0			8.5	yes	
15	0.2		0.0			8.5	yes	
16	0.2		0.0			8.5	yes	
17	0.21		0.0			8.5	yes	
18	0.21		0.0			8.5	yes	
19	0.21		0.0			8.5	yes	
20	0.21		0.0			8.5	yes	
21	0.21		0.0			8.5	yes	
22	0.21		0.0			8.5	yes	
23	0.2		0.0			8.5	yes	
24	0.2		0.0			8.5	yes	
25	0.2		0.0			8.5	yes	
26	0.2		0.0			8.5	yes	
27	0.2		0.0			8.5	yes	
28	0.2		0.0			8.5	yes	
29	0.21		0.0			8.5	yes	
30	0.21		0.0			8.5	yes	
31							yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350