

Oregon DHS - Drinking Water Program - Turbidity Monitoring Report Form

System Name: Brighton Water Co

ID #: 41 05104

Month/Year: DEC 2022

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1				.55				
2				.45				
3				.40				
4				.35				
5				.35				
6				.30				
7				.30				
8				.30				
9				.32				
10				.32				
11				.30				
12				.30				
13				.28				
14				.28				
15				.28				
16				.25				
17				.25				
18				.27				
19				.27				
20				.30				
21				.30				
22				.35				
23				.35				
24				.33				
25				.35				
26				.35				
27				.40				
28				.45				
29				.50				
30				.43				
31				.40				

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)		
% of turbidity readings ≤ 0.3 NTU? <u>Yes / No</u> % of turbidity readings < 1 NTU? <u>Yes / No</u> % of turbidity readings < 1 IFE triggers? <u>Yes / No</u> ¹		CT's met everyday? (see back) <u>Yes / No</u>	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <u>Yes / No</u>	Cl ₂ residual measured in 95% of distribution samples? <u>Yes / No</u>
- OR -		PRINTED NAME: <u>Sherri Stewart</u>		
% of turbidity readings ≤ 1 NTU? <u>Yes / No</u> % of turbidity readings < 5 NTU? <u>Yes / No</u>		SIGNATURE: <u>Sherri Stewart</u>		DATE: <u>1-5-2023</u>
		PHONE #: <u>(503) 647-6485</u>		CERT #: <u>6</u>

¹ IFE = Individual Filter Effluent

Oregon DHS - Drinking Water Program - Surface Water Quality Data Form

System Name: Brighton Water Co

ID #: 41 05104

Month/Year: DEC 2020

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?
	ppm or mg/L	minutes	C X T	°C		Use tables	Yes / No
1 /	.20						
2 /	.20						
3 /	.20						
4 /	.21						
5 /	.21						
6 /	.21						
7 /	.22						
8 /	.22						
9 /	.21						
10 /	.21						
11 /	.20						
12 /	.20						
13 /	.20						
14 /	.21						
15 /	.21						
16 /	.22						
17 /	.22						
18 /	.22						
19 /	.22						
20 /	.21						
21 /	.21						
22 /	.21						
23 /	.21						
24 /	.21						
25 /	.20						
26 /	.20						
27 /	.20						
28 /	.20						
29 /	.20						
30 /	.20						
31 /	.20						