

OHA - DWS

Lincoln Co.

PWS ID#: 41 - **05108**
 Plant ID: WTP - **11225**
 (e.g., "A")

Minimum test pressure applied: **22.48** psi
 Minimum test pressure req'd: **22** psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇨
 PDR = Pressure Decay Rate
 LRC = Log Removal Credit

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 minutes)	Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	DIT Daily [Y/N] or "off"
1	0.004	0.004	0.004	0.096		Y
2	0.005	0.005	0.005	0.096		Y
3	0.005	0.005	0.005	0.096		Y
4	0.005	0.005	0.005	0.096		Y
5	0.007	0.007	0.007	0.105		Y
6	0.005	0.005	0.005	0.105		Y
7	0.005	0.005	0.005	0.105		Y
8	2.900	2.9	2.900	0.105		Y
9	1.595	1.595	1.595	0.105		Y
10	0.005	0.005	0.005	0.105		Y
11	0.005	0.005	0.005	0.105		Y
12	3.215	3.215	3.215	0.105		Y
13	0.005	0.005	0.005	0.105		Y
14	4.997	4.997	4.997	0.105		Y
15	0.007	0.007	0.007	0.105		Y
16	0.005	0.005	0.005	0.105		Y
17	0.005	0.005	0.005	0.105		Y
18	0.006	0.006	0.006	0.105		Y
19	0.007	0.007	0.007	0.105		Y
20	0.006	0.006	0.006	0.105		Y
21	0.005	0.005	0.005	0.105		Y
22	0.005	0.005	0.005	0.105		Y
23	0.511	0.511	0.511	0.105		Y
24	0.031	0.031	0.031	0.105		Y
25	0.006	0.006	0.006	0.105		Y
26	0.007	0.007	0.007	0.105		Y
27	4.463	4.463	4.463	0.105		Y
28	2.116	2.116	2.116	0.105		Y
29	3.928	3.298	3.298	0.105		Y
30	0.006	0.006	0.006	0.105		Y
31						

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR $\leq$ PDR _{Max} , LRV $\geq$ LRC)	DIT Daily?
No	Yes	No	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR $\leq$ PDR _{Max} ?	LRV _{ambient} $\geq$ LRC?	
Yes	Yes	Yes		

PRINTED NAME:
 SIGNATURE: 
 NOTES: see attached email

Dave Huber

DATE: 7-5-25
 WT CERT #: D-129526
 PHONE #: 541-272-0711

p. 1 of 2

Disinfection Monthly Operating Report

System Name: Trollers Cove Water AssociationPWS ID#: 41 - 05108Plant ID : WTP - 11225

0.5

Log
Inactivation
Required via
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	1.535	40	61.4	12.2	7.20	19.0	YES	20	
2	1.121	40	44.8	13.0	7.18	16.8	YES	20	
3	1.039	40	41.6	13.0	7.18	16.7	YES	20	
4	1.270	40	50.8	13.0	7.20	17.3	YES	20	
5	1.560	40	62.4	13.3	7.25	17.8	YES	20	
6	1.187	40	47.5	13.5	7.23	16.7	YES	20	
7	1.160	40	46.4	13.9	7.20	16.1	YES	20	
8	1.220	40	48.8	13.8	7.29	16.8	YES	20	Chem. CLN
9	1.209	40	48.4	14.5	7.24	15.8	YES	20	
10	1.210	40	48.4	14.3	7.26	16.1	YES	20	
11	1.100	40	44.0	14.3	7.26	15.9	YES	20	i/net out 30 mins
12	1.152	40	46.1	13.8	7.28	16.6	YES	20	
13	1.162	40	46.5	13.0	7.31	17.7	YES	20	
14	1.425	40	57.0	13.0	7.32	18.4	YES	20	
15	1.271	40	50.8	12.4	7.33	19.1	YES	20	
16	1.209	40	48.4	13.0	7.31	17.8	YES	20	
17	1.203	40	48.1	13.5	7.31	17.2	YES	20	
18	1.239	40	49.6	13.3	7.33	17.7	YES	20	
19	1.810	40	72.4	13.2	7.32	18.9	YES	20	
20	1.105	40	44.2	13.3	7.33	17.4	YES	20	
21	0.791	40	31.6	13.0	7.29	16.9	YES	20	CL dilution error
22	0.450	40	18.0	13.3	7.28	15.9	YES	20	Adjust dilution
23	0.511	40	20.4	13.8	7.29	15.5	YES	20	
24	1.211	40	48.4	13.8	7.30	16.9	YES	20	
25	2.450	40	98.0	14.1	7.37	19.6	YES	20	
26	2.068	40	82.7	14.1	7.41	19.1	YES	20	
27	1.979	40	79.2	14.4	7.41	18.5	YES	20	
28	1.799	40	72.0	14.5	5.61	9.1	YES	20	
29	1.995	40	79.8	15.0	5.85	9.9	YES	20	
30	1.760	40	70.4	14.8	7.13	15.8	YES	20	
31									

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dlwp.dnce@odhsoha.oregon.gov

fax: 971-673-0458

p. 2 of 2