

# OHA - DWS

## Membrane Filter Monthly Operating Report

County: **Lincoln**

System Name: **Trollers Cove Water Assoc.**

Month/Year: **December '25**

PWS ID#: 41 - **05108**

Minimum test pressure applied: **22.48** psi

Plant ID: WTP - **DECEMBER Compliance**  
(e.g., "A")

Minimum test pressure req'd: **22** psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇄

PDR = Pressure Decay Rate

LRC = Log Removal Credit

**PDR<sub>Max</sub> [psi/min]**

**0.099**

**LRC [log removal]**

**4.00**

**DIT Daily**

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 minutes)	Highest PDR of day [psi/min]	Lowest LRV <sub>ambient</sub> of day [log removal]	[Y/N] or "off"
1	0.006	0.006	0.006	0.249		N
2	0.006	0.006	0.006	0.249		N
3	0.006	0.006	0.006	Fail		N
4	0.006	0.006	0.006	0.249		N
5	0.006	0.006	0.006	0.249		N
6	0.006	0.006	0.006	0.249		N
7	0.014	0.014	0.014	0.249		N
8	0.007	0.007	0.007	0.249		N
9	0.015	0.015	0.005	0.249		N
10	0.007	0.007	0.007	0.249		N
11	0.007	0.007	0.007	0.276		N
12	0.007	0.007	0.007	0.249		N
13	0.014	0.014	0.014	0.249		N
14	0.011	0.011	0.011	0.249		N
15	0.014	0.014	0.014	0.249		N
16	0.009	0.009	0.009	0.249		N
17	0.017	0.017	0.017	0.249		N
18	0.014	0.014	0.014	Fail		N
19	0.010	0.01	0.010	fail		N
20	0.006	0.006	0.006	0.249		N
21	0.006	0.006	0.006	0.249		N
22	0.007	0.007	0.007	0.332		N
23	0.005	0.005	0.005	0.275		N
24	0.006	0.006	0.006	0.320		N
25	0.006	0.006	0.006	0.254		N
26	0.006	0.006	0.006	0.254		N
27	0.005	0.005	0.005	0.254		N
28	0.006	0.005	0.005	0.249		N
29	0.006	0.006	0.006	0.254		N
30	0.006	0.006	0.006	0.254		N
31	0.006	0.005	0.005	0.249		N

**Compliance summary (operator to complete any blank fields)**

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR <sub>Max</sub> , LRV ≥ LRC)	DIT Daily?
<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>No</b>	<b>No</b>
CT's met daily? (p. 2)	All Cl <sub>2</sub> residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR <sub>Max</sub> ?	LRV <sub>ambient</sub> ≥ LRC?	
<b>Yes</b>	<b>Yes</b>	<b>No</b>		

PRINTED NA Dave Huber

SIGNATURE:

DATE:

5-Feb-26

WT CERT #:

D129526

\* Used for optimization purposes only.