

OHA - DWS

Membrane Filter Monthly Operating Report

County: **Lincoln**

System Name: **Trollers Cove Water Assoc.**

Month/Year: **Jan-2026**

PWS ID#: 41 - **05108**

Minimum test pressure applied: **22.48** psi

Plant ID: WTP - **Compliance JAN '26**
(e.g., "A")

Minimum test pressure req'd: **22** psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇄

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{Max} [psi/min]

LRC [log removal]

0.099

4.00

**DIT
Daily**

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 minutes)	Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.006	0.006	0.006	0.330		N
2	0.006	0.006	0.006	0.332		N
3	0.007	0.007	0.007	0.332		N
4	0.005	0.005	0.005	0.360		N
5	0.007	0.007	0.007	0.332		N
6	0.006	0.006	0.006	0.360		N
7	0.007	0.007	0.007	0.360		N
8	0.005	0.005	0.005	0.360		N
9	0.005	0.005	0.005	0.360		N
10	0.005	0.005	0.005	0.332		N
11	0.005	0.005	0.005	0.360		N
12	0.005	0.005	0.005	0.360		N
13	0.006	0.006	0.006	0.332		N
14	0.006	0.006	0.006	0.332		N
15	0.005	0.005	0.005	Data lost		N
16	0.005	0.005	0.005	Data lost		N
17	0.005	0.005	0.005	Data lost		N
18	0.005	0.005	0.005	Data lost		N
19	0.006	0.006	0.006	Data lost		N
20	0.007	0.007	0.007	Data lost		N
21	0.005	0.005	0.005	Data lost		N
22	0.006	0.006	0.006	Data lost		N
23	0.005	0.005	0.005	Data lost		N
24	0.006	0.006	0.006	Data lost		N
25	0.007	0.007	0.007	Data lost		N
26	0.007	0.007	0.007	Data lost		N
27	0.007	0.007	0.007	Data lost		N
28	0.008	0.008	0.008	Data lost		N
29	0.006	0.006	0.006	0.360		N
30	0.006	0.006	0.006	0.399		N
31	0.009	0.009	0.009	0.399		N

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	No	No
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	No		

PRINTED NA Dave Huber

SIGNATURE:

DATE: Feb. 05, 2026

WT CERT #:

D129526

* Used for optimization purposes only.