

OHA - Drinking Water Program - Surface Water Quality Data Form

County: **Columbia**

Cartridge or Bag Filtration

Month/Year: **Nov-25**System Name: **PGE - BEAVER GENERATING STATION** ID#: **41 05246** WTP ID: **TP- A**

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	45.00	38.00	7.00	31.00	0.08	0.11
2	48.00	39.00	7.00	31.00	0.07	0.07
3	48.00	40.00	8.00	31.00	0.07	0.13
4	48.00	38.00	10.00	31.00	0.07	0.087
5	48.00	38.00	10.00	31.00	0.07	0.08
6	48.00	38.00	10.00	31.00	0.07	.09 6
7	48.00	38.00	10.00	31.00	0.07	0.097
8	48.00	38.00	10.00	31.00	0.08	0.092
9	49.00	38.00	11.00	31.00	0.07	0.087
10	49.00	38.00	11.00	31.00	0.08	0.123
11	48.00	38.00	10.00	31.00	0.08	0.146
12	48.00	37.00	11.00	31.00	0.16	0.171
13	49.00	36.00	13.00	31.00	0.07	0.165
14	47.00	37.00	10.00	31.00	0.07	0.103
15	48.00	37.00	11.00	31.00	0.07	0.112
16	48.00	37.00	11.00	31.00	0.08	0.191
17	48.00	36.00	12.00	31.00	0.07	0.141
18	49.00	38.00	11.00	31.00	0.07	0.152
19	48.00	37.00	11.00	31.00	0.07	0.367
20	48.00	37.00	11.00	31.00	0.08	0.175
21	49.00	35.00	14.00	31.00	0.07	0.372
22	48.00	37.00	11.00	31.00	0.07	0.118
23	49.00	37.00	12.00	31.00	0.07	0.122
24	48.00	36.00	12.00	31.00	0.07	0.096
25	48.00	37.00	11.00	31.00	0.07	0.098
26	48.00	37.00	11.00	31.00	0.07	0.101
27	48.00	36.00	12.00	31.00	0.07	0.108
28	48.00	36.00	12.00	31.00	0.07	0.076
29	50.00	37.00	13.00	31.00	0.07	0.075
30	50.00	37.00	13.00	31.00	0.07	0.112
31				31.00		

Cartridge & Bag Filtration

95% of daily turbidity readings ≤ 1 NTU?

Yes / No

All daily turbidity readings ≤ 5 NTU?

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l?

Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: **Neal Conley**SIGNATURE: *Neal Conley*PHONE #: **(503)728-7256**CERT#: **T425323
/D-425323**¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

Oregon Health Authority, Drinking Water Services

Monthly UV Disinfection Report for Surface Water Systems Requiring 4-log Viral Inactivation

System Name:

PGE - BEAVER GENERATING STATION

ID#: 41

05246

Month/Year:

Nov-25

Entry Point

Required Minimum Dosage 186 mJ/cm²

Day	Time	Source(s) in Use	Uninterrupted UV Operation? (i.e., No Alarms = Yes)	Notes
1	11:35	Entry Point A	YES	
2	7:35	Entry Point A	YES	
3	9:00	Entry Point A	YES	
4	7:00	Entry Point A	YES	
5	9:00	Entry Point A	YES	
6	7:00	Entry Point A	YES	
7	7:30	Entry Point A	YES	
8	5:30	Entry Point A	YES	
9	7:25	Entry Point A	YES	
10	6:38	Entry Point A	YES	
11	7:40	Entry Point A	YES	
12	6:29	Entry Point A	YES	
13	6:19	Entry Point A	YES	
14	6:35	Entry Point A	YES	
15	6:05	Entry Point A	YES	
16	6:45	Entry Point A	YES	
17	7:35	Entry Point A	YES	
18	5:45	Entry Point A	YES	
19	5:15	Entry Point A	YES	
20	5:00	Entry Point A	YES	
21	10:05	Entry Point A	YES	
22	8:40	Entry Point A	YES	
23	8:35	Entry Point A	YES	
24	6:00	Entry Point A	YES	
25	6:40	Entry Point A	YES	
26	6:30	Entry Point A	YES	
27	5:58	Entry Point A	YES	
28	10:00	Entry Point A	YES	
29	5:50	Entry Point A	YES	
30	7:30	Entry Point A	YES	
31		Entry Point A	YES	

If answered no above, what was the longest time period until UV operation was restored?

hrs

If UV stopped working during water production, was DWS contacted?

Was a boil notice (Tier 1 Public Notice) issued?

If not, please explain:

Date & time UV reactor failed:

/ / :

Date & time it was returned to service:

/ / :