

OHA - Drinking Water Program - Surface Water Quality Data Form

County: **Columbia**

Cartridge or Bag Filtration

Month/Year: **Jan-26**

System Name: **PGE - BEAVER GENERATING STATION** ID#: **41 05246** WTP ID: **TP- A**

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	38.00	35.00	3.00	31.00	0.07	0.074
2	37.00	35.00	2.00	31.00	0.07	0.082
3	38.00	35.00	3.00	31.00	0.07	0.125
4	38.00	35.00	3.00	31.00	0.06	0.064
5	38.00	34.00	4.00	31.00	0.07	0.108
6	38.00	34.00	4.00	31.00	0.06	0.142
7	38.00	34.00	4.00	31.00	0.06	0.067
8	38.00	34.00	4.00	31.00	0.07	0.069
9	37.00	34.00	3.00	31.00	0.07	0.12
10	38.00	34.00	4.00	31.00	0.08	0.153
11	38.00	34.00	4.00	31.00	0.07	0.14
12	37.00	34.00	3.00	31.00	0.07	0.08
13	37.00	34.00	3.00	31.00	0.07	0.076
14	37.00	34.00	3.00	31.00	0.08	0.082
15	37.00	34.00	3.00	31.00	0.08	0.12
16	37.00	34.00	3.00	31.00	0.07	0.133
17	37.00	34.00	3.00	31.00	0.07	0.119
18	38.00	35.00	3.00	31.00	0.07	0.145
19	38.00	34.00	4.00	31.00	0.06	0.128
20	38.00	34.00	4.00	31.00	0.07	0.117
21	37.50	34.00	3.50	31.00	0.06	0.094
22	37.50	34.00	3.50	31.00	0.07	0.067
23	37.00	34.00	3.00	31.00	0.07	0.096
24	38.00	34.00	4.00	31.00	0.07	0.096
25	41.00	37.00	4.00	31.00	0.06	0.069
26	40.00	37.00	3.00	31.00	0.07	0.089
27	40.00	36.00	4.00	31.00	0.07	0.103
28	40.00	36.00	4.00	31.00	0.06	0.7
29	40.00	36.00	4.00	31.00	0.06	0.067
30	41.00	37.00	4.00	31.00	0.06	0.092
31	41.00	38.00	3.00	31.00	0.07	0.118

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: Neal Conley SIGNATURE: <i>Neal Conley</i> 2/1/26 PHONE #: (503)728-7256 CERT#: T425323 / D-425323	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

Oregon Health Authority, Drinking Water Services

Monthly UV Disinfection Report for Surface Water Systems Requiring 4-log Viral Inactivation

PGE - BEAVER GENERATING STATION

ID#: 41 05246

System Name:

Month/Year:

Jan-26

Entry Point

Required Minimum Dosage 186 mj/cm2

Day	Time	Source(s) in Use	Uninterrupted UV Operation? (i.e., No Alarms = Yes)	Notes
1	6:30	Entry Point A	YES	
2	8:00	Entry Point A	YES	
3	6:00	Entry Point A	YES	
4	7:00	Entry Point A	YES	
5	8:35	Entry Point A	YES	
6	7:25	Entry Point A	YES	
7	6:00	Entry Point A	YES	
8	6:15	Entry Point A	YES	
9	5:20	Entry Point A	YES	
10	7:30	Entry Point A	YES	
11	7:10	Entry Point A	YES	
12	6:00	Entry Point A	YES	
13	9:00	Entry Point A	YES	
14	6:00	Entry Point A	YES	
15	6:00	Entry Point A	YES	
16	12:00	Entry Point A	YES	
17	6:40	Entry Point A	YES	
18	6:00	Entry Point A	YES	
19	7:35	Entry Point A	YES	
20	8:32	Entry Point A	YES	
21	11:34	Entry Point A	YES	
22	10:39	Entry Point A	YES	
23	5:30	Entry Point A	YES	
24	8:54	Entry Point A	YES	
25	6:05	Entry Point A	YES	
26	5:50	Entry Point A	YES	
27	5:35	Entry Point A	YES	
28	5:55	Entry Point A	YES	
29	5:35	Entry Point A	YES	
30	6:45	Entry Point A	YES	
31	6:10	Entry Point A	YES	

If answered no above, what was the longest time period until UV operation was restored? _____ hrs

If UV stopped working during water production, was DWS contacted?

Was a boil notice (Tier 1 Public Notice) issued?

If not, please explain:

Date & time UV reactor failed: _____ : _____ Date & time it was returned to service: _____ : _____