

OHA - Drinking Water Program - Surface Water Quality Data Form

County: **Columbia**

Cartridge or Bag Filtration

Month/Year: **Dec-22**

System Name: **PGE - BEAVER GENERATING STATION** ID#: **41 05246** WTP ID: **TP- A**

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	32.00	24.00	8.00		0.30	0.329
2	37.00	34.00	3.00		0.08	0.329
3	34.00	28.00	6.00		0.05	0.216
4	32.00	29.00	3.00		0.05	0.11
5	32.00	28.00	4.00		0.04	0.094
6	32.00	28.00	4.00		0.05	0.177
7	36.00	30.00	6.00		0.05	0.196
8	30.00	26.00	4.00		0.05	0.188
9	34.00	30.00	4.00		0.04	0.162
10	33.00	29.00	4.00		0.04	0.166
11	34.00	29.00	5.00		0.06	0.144
12	34.00	30.00	4.00		0.05	0.103
13	34.00	34.00	0.00		0.04	0.144
14	33.00	31.00	2.00		0.05	0.27
15	34.00	31.00	3.00		0.06	0.14
16	34.00	31.00	3.00		0.05	0.221
17	36.00	32.00	4.00		0.04	0.141
18	33.00	29.00	4.00		0.04	0.148
19	34.00	30.00	4.00		0.06	0.173
20	34.00	29.00	5.00		0.05	0.227
21	33.00	28.00	5.00		0.04	0.227
22	33.00	28.00	5.00		0.05	0.161
23	33.00	28.00	5.00		0.04	0.221
24	33.00	29.00	4.00		0.06	0.165
25	33.00	29.00	4.00		0.05	0.266
26	34.00	29.00	5.00		0.06	0.229
27	33.00	28.00	5.00		0.07	0.261
28	35.00	30.00	5.00		0.05	0.25
29	34.00	29.00	5.00		0.05	0.179
30	35.00	30.00	5.00		0.11	0.127
31	35.00	29.00	6.00		0.04	0.195

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: Neal Conley	
	SIGNATURE: <i>Neal Conley</i>	1/5/2022
	PHONE #: (503)728-7256	CERT#: T425323 /D-425323

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

Oregon Health Authority, Drinking Water Services

Monthly UV Disinfection Report for Surface Water Systems Requiring 4-log Viral Inactivation

System Name:

PGE - BEAVER GENERATING STATION

ID#: 41

05246

Month/Year:

Dec-22

Entry Point

Required Minimum Dosage 186 mJ/cm2

Day	Time	Source(s) in Use	Uninterrupted UV Operation? (i.e., No Alarms = Yes)	Notes
1	5:00	Entry Point A	YES	
2	5:25	Entry Point A	YES	
3	6:00	Entry Point A	YES	
4	6:20	Entry Point A	YES	
5	5:10	Entry Point A	YES	
6	7:00	Entry Point A	YES	
7	8:45	Entry Point A	YES	
8	5:55	Entry Point A	YES	
9	7:20	Entry Point A	YES	
10	8:35	Entry Point A	YES	
11	6:45	Entry Point A	YES	
12	9:00	Entry Point A	YES	
13	8:10	Entry Point A	YES	
14	5:30	Entry Point A	YES	
15	7:15	Entry Point A	YES	
16	7:40	Entry Point A	YES	
17	6:30	Entry Point A	YES	
18	6:30	Entry Point A	YES	
19	7:20	Entry Point A	YES	
20	6:10	Entry Point A	YES	
21	6:05	Entry Point A	YES	
22	7:10	Entry Point A	YES	
23	8:05	Entry Point A	YES	
24	5:15	Entry Point A	YES	
25	5:20	Entry Point A	YES	
26	5:20	Entry Point A	YES	
27	6:25	Entry Point A	YES	
28	8:20	Entry Point A	YES	
29	6:20	Entry Point A	YES	
30	8:00	Entry Point A	YES	
31	5:40	Entry Point A	YES	

If answered no above, what was the longest time period until UV operation was restored? _____ hrs
 If UV stopped working during water production, was DWS contacted?
 Was a boil notice (Tier 1 Public Notice) issued?
 If not, please explain:

Date & time UV reactor failed: / / : :	Date & time it was returned to service: / / : :
---	--