

OHA - Drinking Water Program - Surface Water Quality Data Form

County: **Columbia**

Cartridge or Bag Filtration

Month/Year: **Sep-24**

System Name: **PGE - BEAVER GENERATING STATION** ID#: **41 05246** WTP ID: **TP- A**

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	30.00	30.00	0.00	31.00	0.07	0.114
2	30.00	30.00	0.00	31.00	0.06	0.188
3	30.00	30.00	0.00	31.00	0.06	0.254
4	30.00	30.00	0.00	31.00	0.05	0.106
5	30.00	30.00	0.00	31.00	0.05	0.214
6	30.00	30.00	0.00	31.00	0.07	0.085
7	30.00	30.00	0.00	31.00	0.07	0.086
8	30.00	30.00	0.00	31.00	0.06	0.087
9	29.00	30.00	1.00	31.00	0.07	0.095
10	30.00	30.00	0.00	31.00	0.06	0.096
11	30.00	30.00	0.00	31.00	0.06	0.173
12	30.00	30.00	0.00	31.00	0.07	0.09
13	30.00	30.00	0.00	31.00	0.06	0.08
14	30.00	30.00	0.00	31.00	0.06	0.092
15	30.00	30.00	0.00	31.00	0.07	0.089
16	30.00	30.00	0.00	31.00	0.07	0.076
17	30.00	30.00	0.00	31.00	0.06	0.081
18	31.00	31.00	0.00	31.00	0.07	0.479
19	30.00	30.00	0.00	31.00	0.07	0.087
20	30.00	30.00	0.00	31.00	0.06	0.584
21	30.00	30.00	0.00	31.00	0.12	1.331
22	30.00	30.00	0.00	31.00	0.58	0.86
23	30.00	30.00	0.00	31.00	0.06	0.098
24	30.00	30.00	0.00	31.00	0.06	0.073
25	30.00	30.00	0.00	31.00	0.06	0.075
26	30.00	30.00	0.00	31.00	0.06	1.22
27	30.00	30.00	0.00	31.00	0.06	0.124
28	30.00	30.00	0.00	31.00	0.06	0.078
29	30.00	30.00	0.00	31.00	0.06	0.079
30	31.00	30.00	1.00	31.00	0.67	0.72
31				31.00		

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l?	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch		PRINTED NAME: Neal Conley	
PSID = pounds per square inch difference (before filter - after filter)		SIGNATURE: <i>Neal Conley</i> 10/10/24	
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		PHONE #: (503)728-7256	CERT#: T425323 /D-425323

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

Oregon Health Authority, Drinking Water Services

Monthly UV Disinfection Report for Surface Water Systems Requiring 4-log Viral Inactivation

System Name:

PGE - BEAVER GENERATING STATION

ID#: 41

05246

Month/Year:

Sep-24

Entry Point

Required Minimum Dosage 186 mJ/cm2

Day	Time	Source(s) in Use	Uninterrupted UV Operation? (i.e., No Alarms = Yes)	Notes
1	8:00	Entry Point A	YES	
2	8:00	Entry Point A	YES	
3	8:00	Entry Point A	YES	
4	8:00	Entry Point A	YES	
5	8:00	Entry Point A	YES	
6	8:00	Entry Point A	YES	
7	8:00	Entry Point A	YES	
8	8:00	Entry Point A	YES	
9	8:00	Entry Point A	YES	
10	8:00	Entry Point A	YES	
11	8:00	Entry Point A	YES	
12	8:00	Entry Point A	YES	
13	8:00	Entry Point A	YES	
14	8:00	Entry Point A	YES	
15	8:00	Entry Point A	YES	
16	8:00	Entry Point A	YES	
17	8:00	Entry Point A	YES	
18	8:00	Entry Point A	YES	
19	8:00	Entry Point A	YES	
20	8:00	Entry Point A	YES	
21	8:00	Entry Point A	YES	
22	8:00	Entry Point A	YES	
23	8:00	Entry Point A	YES	
24	8:00	Entry Point A	YES	
25	8:00	Entry Point A	YES	
26	8:00	Entry Point A	YES	
27	8:00	Entry Point A	YES	
28	8:00	Entry Point A	YES	
29	8:00	Entry Point A	YES	
30	8:00	Entry Point A	YES	
31		Entry Point A	YES	

If answered no above, what was the longest time period until UV operation was restored? _____ hrs
 If UV stopped working during water production, was DWS contacted?
 Was a boil notice (Tier 1 Public Notice) issued?
 If not, please explain:

Date & time UV reactor failed: / / : :	Date & time it was returned to service: / / : :
---	--