

OHA - Drinking Water Services - Surface Water Quality Data Form
Cartridge or Bag Filtration

County: Coos
Month/Year: May 2025

System Name		Weiss Estates Water		ID#: 41-05581	WTP ID: TP-1	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU] Highest Reading of the day ¹ [NTU]
1	32.00	30.00	2.00	5.00	0.000000	0.000000
2	32.00	31.00	1.00	5.00	0.000000	0.000000
3	0.00	0.00	0.00	5.00	0.000000	0.000000
4	0.00	0.00	0.00	5.00	0.000000	0.000000
5	0.00	0.00	0.00	5.00	0.000000	0.000000
6	0.00	0.00	0.00	5.00	0.000000	0.000000
7	0.00	0.00	0.00	5.00	0.02	0.02
8	0.00	0.00	0.00	5.00	0.02	0.02
9	0.00	0.00	0.00	5.00	0.03	0.03
10	0.00	0.00	0.00	5.00	0.02	0.02
11	0.00	0.00	0.00	5.00	0.02	0.02
12	38.00	38.00	0.00	5.00	0.02	0.02
13	38.00	36.00	2.00	5.00	0.02	0.02
14	38.00	36.00	2.00	5.00	0.03	0.03
15	0.00	0.00	0.00	5.00	0.03	0.03
16	0.00	0.00	0.00	5.00	0.03	0.03
17	37.00	36.00	1.00	5.00	0.02	0.02
18	37.00	36.00	1.00	5.00	0.02	0.02
19	0.00	0.00	0.00	5.00	0.03	0.03
20	0.00	0.00	0.00	5.00	0.03	0.03
21	0.00	0.00	0.00	5.00	0.03	0.03
22	30.00	30.00	0.00	5.00	0.02	0.02
23	31.00	30.00	1.00	5.00	0.03	0.03
24	30.00	30.00	0.00	5.00	0.03	0.03
25	30.00	30.00	0.00	5.00	0.03	0.03
26	0.00	0.00	0.00	5.00	0.04	0.04
27	0.00	0.00	0.00	5.00	0.33	0.33
28	35.00	33.00	2.00	5.00	0.34	0.34
29	31.00	30.00	1.00	5.00	0.32	0.32
30	30.00	30.00	0.00	5.00	0.31	0.31
31	30.00	30.00	0.00	5.00	0.31	0.31

Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes	CT's met everyday? (see back) Yes
All daily turbidity readings ≤ 5 NTU? Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when	PRINTED NAME: Michael Murphy	
	SIGNATURE: Electronic submit	DATE: 6/8/2025
	PHONE #: (541)253-6191	CERT #: T-09453

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum. **NOTE: Turbidimeter malfunction May 1-6.**

as – Monthly UV Disinfection Reportfor Surface Water Systems Requi

County

Coos

May 2025

System Name	Weiss Estates V	PWS ID# 41 -05581		
Entry Point treatment plant		Required Minimum Dose		
Date	Time	Source(s) in use	Uninterrupted UV Operation	Notes
1			Yes	0.2
2			Yes	0.3
3			Yes	0.3
4			Yes	0.3
5			Yes	0.2
6			Yes	0.2
7			Yes	0.2
8			Yes	0.4
9			Yes	0.4
10			Yes	0.4
11			Yes	0.3
12			Yes	0.2
13			Yes	0.2
14			yes	0.2
15		Fahy Lake	Yes	0.4
16			yes	0.4
17			yes	0.4
18			yes	0.3
19			yes	0.3
20			yes	0.2
21			yes	0.2
22			yes	0.4
23			yes	0.4
24			yes	0.3
25			yes	0.3
26			yes	0.3
27			yes	0.2
28			yes	0.2
29			yes	0.45
30			yes	0.45
31			Yes	0.45

If answered no above, what was the longest time period until UV operation was restored? hoursIf UV stopped working during w

N/A Date & time UV reactor failed: Date & time it was returned to service: / /