

OHA - Drinking Water Services - Surface Water Quality Data Form

Cartridge or Bag Filtration

County:

Coos

Month/Year:

June 2025

System Narr		Weiss Estates Water		ID#: 41-05581	WTP ID:	TP-1
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]Highest Reading of the day ¹ [NTU]
1	0.00	0.00	0.00	25.00	0.04	0.04
2	0.00	0.00	0.00	25.00	0.05	0.05
3	30.00	30.00	0.00	25.00	0.03	0.03
4	0.00	0.00	0.00	25.00	0.06	0.06
5	30.00	30.00	0.00	25.00	0.32	0.32
6	0.00	0.00	0.00	25.00	0.06	0.06
7	0.00	0.00	0.00	25.00	0.07	0.07
8	30.00	30.00	0.00	25.00	0.31	0.31
9	0.00	0.00	0.00	25.00	0.07	0.07
10	25.00	25.00	0.00	25.00	0.08	0.08
11	24.00	24.00	0.00	25.00	0.08	0.08
12	22.00	22.00	0.00	25.00	0.08	0.08
13	0.00	0.00	0.00	25.00	0.09	0.09
14	30.00	30.00	0.00	25.00	0.10	0.10
15	30.00	30.00	0.00	25.00	0.10	0.10
16	0.00	0.00	0.00	25.00	0.12	0.12
17	34.00	32.00	2.00	25.00	0.12	0.12
18	33.00	31.00	2.00	25.00	0.13	0.13
19	32.00	29.00	3.00	25.00	0.13	0.13
20	35.00	31.00	4.00	25.00	0.14	0.14
21	34.00	29.00	5.00	25.00	0.14	0.14
22	28.00	24.00	4.00	25.00	0.14	0.14
23	0.00	0.00	0.00	25.00	0.19	0.19
24	33.00	28.00	5.00	25.00	0.19	0.19
25	40.00	35.00	5.00	25.00	0.16	0.16
26	0.00	0.00	0.00	25.00	0.19	0.19
27	40.00	35.00	5.00	25.00	0.19	0.19
28	40.00	35.00	5.00	25.00	0.20	0.20
29	0.00	0.00	0.00	25.00	0.22	0.22
30	40.00	34.00	6.00	25.00	0.24	0.24
					Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?				Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				Yes	Yes	Yes
Notes: PSI = pounds per square inch					PRINTED NAME: Michael Murphy	
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE: Electronic submit	
PSID When to Change Filter = look in manual for manufacturer's specifications when					DATE: 7/7/2025	
					PHONE #: (541)253-6191	
					CERT #: T-09453	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

as – Monthly UV Disinfection Reportfor Surface Water Systems Requ

County Coos

June 2025

System Name		Weiss Estates v		PWS ID# 41 -05581	
Entry Point treatment plant					Required Minimum Dose
Date	Time	Source(s) in use	Uninterrupted UV Operation	Notes	
1			Yes	0.45	
2			Yes	0.45	
3			Yes	0.45	
4			Yes	0.43	
5			Yes	0.41	
6			Yes	0.50	
7			Yes	0.50	
8			Yes	0.48	
9			Yes	0.46	
10			Yes	0.45	
11			Yes	0.45	
12			Yes	0.65	
13			Yes	0.65	
14			yes	0.67	
15		Fahy Lake	Yes	0.69	
16			yes	0.73	
17			yes	0.73	
18			yes	0.79	
19			yes	0.84	
20			yes	0.87	
21			yes	0.94	
22			yes	0.94	
23			yes	1.02	
24			yes	1.05	
25			yes	1.05	
26			yes	1.20	
27			yes	1.02	
28			yes	1.18	
29			yes	1.16	
30			yes	1.15	
If answered no above, what was the longest time period until UV operation was restored? hoursIf UV stopped working during w					
N/A Date & time UV reactor failed: Date & time it was returned to service: / /					