

OHA - Drinking Water Services - Surface Water Quality Data Form
Cartridge or Bag Filtration

County: **Coos**Month/Year: **September 2025**

System Name		Weiss Estates Water		ID#: 41-05581	WTP ID: TP-1	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU] Highest Reading of the day ¹ [NTU]
1	24.00	24.00	0.00	5.00	0.01	0.01
2	21.00	21.00	0.00	5.00	0.01	0.01
3	18.00	18.00	0.00	5.00	0.01	0.01
4	10.00	10.00	0.00	5.00	0.01	0.01
5	15.00	15.00	0.00	5.00	0.01	0.01
6	5.00	5.00	0.00	5.00	0.01	0.01
7	2.00	2.00	0.00	5.00	0.01	0.01
8	34.00	34.00	0.00	5.00	0.01	0.01
9	37.00	37.00	0.00	5.00	0.01	0.01
10	33.00	33.00	0.00	5.00	0.02	0.01
11	0.00	0.00	0.00	5.00	0.02	0.02
12	33.00	33.00	0.00	5.00	0.02	0.02
13	32.00	32.00	0.00	5.00	0.02	0.02
14	32.00	30.00	2.00	5.00	0.02	0.02
15	32.00	31.00	1.00	5.00	0.02	0.02
16	29.00	29.00	0.00	5.00	0.02	0.02
17	28.00	28.00	0.00	5.00	0.02	0.02
18	27.00	27.00	0.00	5.00	0.02	0.02
19	25.00	25.00	0.00	5.00	0.02	0.02
20	0.00	0.00	0.00	5.00	0.02	0.02
21	25.00	25.00	0.00	5.00	0.02	0.02
22	20.00	20.00	0.00	5.00	0.02	0.02
23	20.00	20.00	0.00	5.00	0.02	0.02
24	19.00	19.00	0.00	5.00	0.02	0.02
25	29.00	29.00	0.00	5.00	0.02	0.02
26	25.00	25.00	0.00	5.00	0.02	0.02
27	24.00	24.00	0.00	5.00	0.02	0.02
28	25.00	25.00	0.00	5.00	0.02	0.02
29	24.00	24.00	0.00	5.00	0.02	0.02
30	32.00	32.00	0.00	5.00	0.01	0.01
					Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?				Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				Yes	Yes	Yes
Notes: PSI = pounds per square inch					PRINTED NAME: Michael Murphy	
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE: Electronic submit	DATE: 10/7/2025
PSID When to Change Filter = look in manual for manufacturer's specifications when					PHONE #: (541)253-6191	CERT #: T-09453

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

System Name: Weiss Estates Water System

PWS ID# 41 -05581

Entry Point: Treatment Plant

Required Minimum Dose 0.2 mg/l

Date	Time	Source(s) in use	Uninterrupted UV Operation	Notes
1			Yes	0.20
2			Yes	0.32
3			Yes	0.37
4			Yes	0.41
5			Yes	0.41
6			Yes	0.41
7			Yes	0.42
8			Yes	0.42
9			Yes	0.42
10			Yes	0.42
11			Yes	0.42
12			Yes	0.44
13			Yes	0.44
14			yes	0.47
15		Fahy Lake	Yes	0.47
16			yes	0.49
17			yes	0.49
18			yes	0.50
19			yes	0.50
20			yes	0.48
21			yes	0.47
22			yes	0.46
23			yes	0.46
24			yes	0.45
25			yes	0.45
26			yes	0.45
27			yes	0.42
28			yes	0.38
29			yes	0.33
30			yes	0.25
If answered no above, what was the longest time period until UV operation was restored? hoursIf UV stopped working during				

N/A

Date & time UV reactor failed:

Date & time it was returned to service:

/ /