

OHA - Drinking Water Services - Surface Water Quality Data Form
Cartridge or Bag Filtration

County: **Coos**
 Month/Year: **January 2026**

System Nam	Weiss Estates Water			ID#: 41-05581	WTP ID: TP-1	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU] Highest Reading of the day ¹ [NTU]
1	44.00	44.00	0.00	5.00	0.01	0.01
2	0.00	0.00	0.00	5.00	0.01	0.01
3	40.00	40.00	0.00	5.00	0.01	0.01
4	0.00	0.00	0.00	5.00	0.02	0.02
5	40.00	40.00	0.00	5.00	0.01	0.01
6	40.00	40.00	0.00	5.00	0.01	0.01
7	40.00	40.00	0.00	5.00	0.01	0.01
8	0.00	0.00	0.00	5.00	0.02	0.02
9	0.00	0.00	0.00	5.00	0.01	0.01
10	0.00	0.00	0.00	5.00	0.02	0.02
11	41.00	41.00	0.00	5.00	0.01	0.01
12				5.00	0.01	0.01
13				5.00	0.01	0.01
14				5.00	0.01	0.01
15				5.00	0.01	0.01
16				5.00	0.01	0.01
17				5.00	0.01	0.01
18				5.00	0.02	0.02
19	40.00	40.00	0.00	5.00	0.05	0.05
20	0.00	0.00	0.00	5.00	0.02	0.02
21	0.00	0.00	0.00	5.00	0.02	0.02
22	0.00	0.00	0.00	5.00	0.02	0.02
23	0.00	0.00	0.00	5.00	0.02	0.02
24	38.00	38.00	0.00	5.00	0.01	0.01
25	38.00	38.00	0.00	5.00	0.01	0.01
26	0.00	0.00	0.00	5.00	0.01	0.01
27	0.00	0.00	0.00	5.00	0.02	0.02
28	44.00	42.00	2.00	5.00	0.01	0.01
29	43.00	41.00	2.00	5.00	0.01	0.01
30	0.00	0.00	0.00	5.00	0.06	0.06
31	0.00	0.00	0.00	5.00	0.02	0.02

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU? **Yes**
 All daily turbidity readings ≤ 5 NTU? **Yes**

CT's met everyday? (see back) **Yes**
 All Cl2 residual at entry point ≥ 0.2 mg/l? **Yes**

Notes: PSI = pounds per square inch
PSID = pounds per square inch difference (before filter - after filter)
PSID When to Change Filter = look in manual for manufacturer's specifications when

PRINTED NAME: Michael Murphy
SIGNATURE: Electronic submit **DATE: 02/08/2026**
PHONE #: (541)253-6191 **CERT #: T-09453**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

County

System Name: Weiss Estates Water System PWS ID# 41 -05581

Entry Point: Treatment Plant Required Minimum Dose 0.2 mg/l

Date	Time	Source(s) in use	Uninterrupted UV Operation	Notes
1			Yes	0.40
2			Yes	0.39
3			Yes	0.37
4			Yes	0.37
5			Yes	0.37
6			Yes	0.36
7			Yes	0.40
8			Yes	0.40
9			Yes	0.38
10			Yes	0.37
11			Yes	0.36
12			Yes	0.35
13			Yes	0.35
14			yes	0.34
15		Fahy Lake	Yes	0.33
16			yes	0.33
17			yes	0.32
18			yes	0.32
19			yes	0.31
20			yes	0.28
21			yes	0.25
22			yes	0.20
23			yes	0.20
24			yes	0.21
25			yes	0.23
26			yes	0.28
27			yes	0.29
28			yes	0.31
29			yes	0.35
30			yes	0.37
31			yes	0.40

If answered no above, what was the longest time period until UV operation was restored? hours If UV stopped working during

N/A Date & time UV reactor failed: Date & time it was returned to service: / /