



System Name: Weiss Estates Water System PWS ID# 41 -05581

Entry Point: Treatment Plant Required Minimum Dose 0.2 mg/l

Date	Time	Source(s) in use	Uninterrupted UV Operation	Notes
1			Yes	0.40
2			Yes	0.37
3			Yes	0.37
4			Yes	0.36
5			Yes	0.39
6			Yes	0.39
7			Yes	0.38
8			Yes	0.38
9			Yes	0.35
10			Yes	0.34
11			Yes	0.34
12			Yes	0.40
13			Yes	0.40
14			yes	0.38
15		Fahy Lake	Yes	0.37
16			yes	0.37
17			yes	0.33
18			yes	0.32
19			yes	0.30
20			yes	0.30
21			yes	0.29
22			yes	0.28
23			yes	0.28
24			yes	0.26
25			yes	0.35
26			yes	0.30
27			yes	0.30
28			yes	0.29

If answered no above, what was the longest time period until UV operation was restored? hours If UV stopped working during  
 N/A Date & time UV reactor failed: Date & time it was returned to service: / /