

OHA - Drinking Water Services - Surface Water Quality Data Form

Cartridge or Bag Filtration

County: Coos

Month/Year: Feb 2021

System Name:

ID#: 41

WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1					.4	.4
2					.2	.2
3					.6	.6
4	75	47	28	25	.7	.7
5					.2	.2
6					.6	.6
7					.6	.6
8	75	45	30	25	.6	.6
9					.6	.6
10					.7	.7
11					.6	.6
12					.4	.4
13					.5	.5
14					.49	.49
15					.3	.3
16					.4	.4
17					.6	.6
18					.8	.8
19					.8	.8
20					.77	.77
21					.71	.71
22	75	50	25	25	.6	.6
23					.7	.7
24					.7	.7
25					.7	.7
26					.7	.7
27					.7	.7
28					.7	.7
29						
30						
31						

Cartridge & Bag Filtration

95% of daily turbidity readings ≤ 1 NTU?

Yes No

All daily turbidity readings ≤ 5 NTU?

Yes No

Monthly Summary (Answer Yes or No)

CI's met everyday? (see back)

Yes No

All CI2 residual at entry point ≥ 0.2 mg/l?

Yes No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Shawna H. Pinson

SIGNATURE: [Signature]

DATE: 3/2/21

PHONE #: (541) 269-0321

CERT #: P-08796

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

T-08796

OHA - Drinking Water Services - Surface Water Quality Data Form

Month/Year: **Feb. 2025**
 Disinfection **virus** Log **4**
 Inactiv:

System Name: **Belloni Boys Ranch** ID#: **41-05592** WTP-A

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temperature	Required CT (see bottom table - value is based on temperature)	Required CT Met? ²
	[ppm or mg/L]	[minutes]	C X T	[degrees C]	[mg-min/L]	Yes / No
1	.3	148	44.4	8	8	Y
2	1.5	148	222	8	8	X
3	.9	148	133.2	8	8	Y
4	.7	148	103.6	8	8	Y
5	.4	148	59.2	7	8	Y
6	.4	148	59.2	7	8	Y
7	1.3	148	192.4	8	8	Y
8	1.3	148	187.6	8	8	Y
9	1.2	148	88.8	8	8	Y
10	.7	148	103.6	7	8	Y
11	.6	148	88.8	7	8	Y
12	.5	148	74	7	8	Y
13	.4	148	59.2	8	8	Y
14	.7	148	103.6	8	8	Y
15	.2	148	29.6	8	8	Y
16	.2	148	29.6	8	8	Y
17	.2	148	29.6	8	8	Y
18	.3	148	44.4	8	8	Y
19	1.5	148	222	8	8	Y
20	.2	148	29.6	9	8	Y
21	.2	148	29.6	8	8	Y
22	.2	148	29.6	8	8	Y
23	.2	148	29.6	8	8	Y
24	.3	148	44.4	8	8	Y
25	.4	148	59.2	8	8	Y
26	.5	148	74	8	8	Y
27	.4	148	59.2	8	8	Y
28	.4	148	59.2	8	8	Y
29		148				
30		148				
31		148				

² If Cl₂ at entry point < 0.2 mg/l or the CT not met, notify DWS within 24 hours.

Required CT for viral inactivation (for pH range of 6.0 to 9.9)						
Temp (C°)	0-4.9	5.0 - 9.9	10.0 - 14.9	15.0 - 19.9	20 -24.9	≥ 25.0 C
Required CT	12	8	6	4	3	2

Return by 10th of following month by email, fax or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350