

## OHA - Drinking Water Services -Turbidity Monitoring Report Form

## Conventional or Direct Filtration

County:	Columbia
Month/Year:	Dec-22

System Name:		Berndt Creek Water Corp #OR4105737					WTP : TP -	
Day		12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1		0.04	0.03	0.03	0.03	0.03	0.03	0.04
2		0.03	0.03	0.03	0.03	0.03	0.03	0.03
3		0.03	0.03	0.02	0.03	0.02	0.02	0.03
4		0.03	0.03	0.03	0.26	0.18	0.16	0.03
5		0.11	0.08	0.05	0.06	0.04	0.04	0.11
6		0.04	0.04	0.04	0.05	0.04	0.04	0.06
7		0.04	0.03	0.03	0.03	0.03	0.03	0.04
8		0.03	0.12	0.11	0.09	0.11	0.13	0.13
9		0.11	0.08	0.07	0.09	0.11	0.09	0.11
10		0.18	0.24	0.28	0.03	0.03	0.03	0.30
11		0.03	0.03	0.03	0.06	Plant Off	Plant Off	0.29
12		0.22	0.19	0.23	0.14	0.03	0.03	0.24
13		0.03	0.03	0.03	0.03	0.03	0.03	0.04
14		0.03	0.03	0.03	0.03	0.03	0.03	0.04
15		0.03	0.03	0.03	0.03	0.03	0.03	0.04
16		0.03	0.03	0.03	0.03	0.03	0.03	0.04
17		0.03	0.03	0.03	0.04	0.03	0.03	0.04
18		0.03	0.03	0.03	0.04	0.05	0.05	0.13
19		0.05	0.03	0.03	0.03	0.03	0.03	0.05
20		0.03	0.03	0.03	0.03	0.03	0.03	0.04
21		0.03	0.03	0.03	0.03	0.03	0.03	0.03
22		0.03	0.03	0.03	0.03	0.03	0.03	0.04
23		0.03	0.03	0.03	0.04	0.03	0.03	0.04
24		0.03	0.03	0.03	0.03	0.03	0.03	0.04
25		0.03	0.03	0.03	0.03	0.03	0.03	0.04
26		0.03	0.03	0.03	0.03	0.03	0.03	0.04
27		0.03	0.03	0.03	0.05	0.04	0.04	0.05
28		0.04	0.04	0.04	0.04	0.03	0.03	0.04
29		0.03	0.03	0.04	0.03	0.03	0.03	0.04
30		0.03	0.03	0.03	0.03	0.03	0.03	0.04
31		0.03	0.03	0.03	0.03	0.03	0.03	0.03

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>		
95% of 4-hour turbidity readings ≤ 0.3 NTU?		Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?			Yes	Yes
All turbidity readings < IFE <sup>2</sup> triggers				

Notes: Fax 971-673-0694 DWP.DMCE@state.or.us

PRINTED NAME: Joshua Allman	
SIGNATURE: <i>Joshua Allman</i>	DATE: 1/4/23
PHONE #: 503-367-7397	
CERT #:	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	Berndt Creek Water Corp	ID#:	41	05737	Month/Year:	Dec/22	Disinfection Giardia Log Inactivat <sup>n</sup> Req'd:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.0	126	126	7.0	7.0	50	Yes	51
2	.8	1	101	7.1	7.1	58	Yes	68
3	.8	1	101	7.0	7.1	58	Yes	73
4	.7	1	88	7.1	7.1	58	Yes	726
5	1.0	126	6.9	7.1	60	Yes	67	
6	1.1	139	6.9	6.9	51	Yes	60	
7	1.2	151	6.9	6.9	51	Yes	78	
8	1.2	151	7.2	7.0	51	Yes	73	
9	1.2	151	7.2	7.1	61	Yes	76	
10	1.0	126	7.1	7.1	60	Yes	73	
11	1.1	139	7.1	7.0	51	Yes	88	
12	1.1	139	7.1	7.2	61	Yes	68	
13	.9	113	7.5	6.7	50	Yes	53	
14	.89	112	7.5	6.8	50	Yes	53	
15	.8	101	7.5	6.9	49	Yes	69	
16	0.75	94	7.3	7.0	48	Yes	65	
17	.8	101	7.1	7.0	49	Yes	107	
18	0.82	103	7.0	6.8	49	Yes	98	
19	.8	101	7.0	6.9	49	Yes	75	
20	.8	101	7.0	6.7	49	Yes	81	
21	.9	113	6.9	6.9	50	Yes	59	
22	1.0	126	6.9	7.0	50	Yes	125	
23	1.0	126	6.7	7.0	50	Yes	85	
24	.9	113	6.6	6.9	50	Yes	57	
25	.9	113	6.5	6.7	50	Yes	51	
26	.9	113	6.5	6.7	50	Yes	66	
27	.9	113	6.6	6.8	50	Yes	60	
28	.9	113	6.7	6.8	50	Yes	54	
29	0.97	122	6.8	7.0	50	Yes	69	
30	1.07	135	6.9	7.1	61	Yes	88	
31	1.12	141	7.0	7.1	61	Yes	110	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018