



OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:	Columbia
Month/Year:	Jan-24

System Name: Berndt Creek Water Corp		#OR4105737					WTP : TP -
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.03	0.02	0.03	0.03	0.03	0.28
2	0.14	0.15	0.09	0.12	0.18	0.18	0.29
3	0.05	0.02	0.03	0.02	0.02	0.02	0.06
4	0.02	0.02	0.02	0.03	0.02	0.02	0.06
5	0.02	0.02	0.02	0.05	0.12	0.12	0.30
6	Plant Off	Plant Off	0.30	0.04	0.04	0.04	0.30
7	0.03	0.02	0.02	0.02	0.02	0.02	0.11
8	0.02	0.02	0.02	0.02	0.02	0.02	0.10
9	0.02	0.02	0.02	0.02	0.02	0.02	0.06
10	0.02	0.02	0.02	0.02	0.02	0.02	0.05
11	0.02	0.02	0.02	0.02	0.02	0.02	0.05
12	0.03	0.03	0.03	0.02	0.03	0.03	0.11
13	0.02	0.02	0.02	0.03	0.02	0.02	0.05
14	0.02	0.02	0.02	Plant Off	0.02	0.02	0.22
15	0.02	0.02	0.02	0.02	0.02	0.02	0.03
16	0.02	0.02	0.02	0.02	0.02	0.02	0.05
17	0.02	0.02	0.02	0.02	0.02	0.02	0.06
18	0.02	0.02	0.02	0.02	0.02	0.02	0.05
19	0.02	0.02	0.02	0.02	0.02	0.02	0.06
20	0.02	0.02	0.02	0.02	0.02	0.02	0.07
21	0.02	0.02	0.02	0.02	0.02	0.02	0.06
22	0.02	0.02	0.02	0.02	0.02	0.02	0.05
23	0.02	0.02	0.02	0.02	0.02	0.02	0.04
24	0.02	0.02	0.02	0.02	0.02	0.02	0.03
25	0.02	0.02	0.02	0.02	0.02	0.02	0.03
26	0.02	0.02	0.02	0.02	0.02	0.02	0.03
27	0.02	0.02	0.02	0.02	0.02	0.02	0.04
28	0.02	0.02	0.02	0.02	0.02	0.02	0.04
29	0.02	0.02	0.02	0.05	0.02	0.02	0.05
30	0.02	0.02	0.02	0.02	0.02	0.02	0.04
31	0.02	0.02	0.02	0.02	0.02	0.02	0.23
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings ≤ 0.3 NTU?		Yes	CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?		
All 4-hour turbidity readings ≤ 1 NTU?		Yes	Yes		Yes		
All turbidity readings < IFE ² triggers		Yes					
Notes: Fax 971-673-0694 DWP.DMCE@state.or.us							
PRINTED NAME: Joshua Allman SIGNATURE:  PHONE #: 503-367-7397							
DATE:  CERT #:							

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Services – Surface Water Quality Data Form

Month/Year: Jan/24

System Name: Bendt Creek Water Corp			ID# 4105737			WTP		
Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM] Hr
1/	0.99	126	125	8.5	7.2	60	Yes	134
2/	0.88	126	111	8.5	7.2	60	Yes	110
3/	0.85	126	107	8.5	7.2	58	Yes	118
4/	1.00	126	126	8.4	7.3	60	Yes	121
5/	1.07	126	135	8.3	7.2	61	Yes	120
6/	1.09	126	137	8.3	7.2	61	Yes	123
7/	1.13	126	142	8.3	7.1	60	Yes	114
8/	0.88	126	111	8.2	7.1	60	Yes	125
9/	0.88	126	111	8.1	7.1	60	Yes	114
10/	0.88	126	111	8.0	7.1	60	Yes	80
11/	0.89	126	114	7.9	7.1	60	Yes	118
12/	0.89	126	114	7.8	7.1	60	Yes	170
13/	0.89	126	114	7.5	7.1	60	Yes	131
14/	0.89	126	114	7.4	7.1	60	Yes	232
15/	0.86	126	107	7.3	7.2	58	Yes	146
16/	0.86	126	107	7.3	7.2	58	Yes	180
17/	1.1	126	126	7.3	7.1	60	Yes	337
18/	1.1	126	126	7.3	7.1	60	Yes	475
19/	1.1	126	126	7.2	7.1	60	Yes	127
20/	1.1	126	124	7.1	7.1	60	Yes	136
21/	1.1	126	126	7.0	7.1	60	Yes	148
22/	1.3	126	164	7.1	7.1	62	Yes	132
23/	1.3	126	164	7.1	7.1	62	Yes	147
24/	1.2	126	151	7.1	7.1	61	Yes	126
25/	1.2	126	151	7.2	7.1	61	Yes	124
26/	1.2	126	151	7.2	7.1	61	Yes	135
27/	1.2	126	151	7.4	7.1	61	Yes	108
28/	1.2	126	151	7.7	7.1	61	Yes	136
29/	1.2	126	151	7.9	7.0	51	Yes	175
30/	1.2	126	151	8.0	7.1	61	Yes	151
31/	1.2	126	151	8.1	7.0	51	Yes	137

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours.

Revised November 2022

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdfReturn by 10th of following month by email, fax or mail to:dwp.dmc@oha.oregon.gov; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR

97293-0350

PAGE 2 of 2