


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Jan-21

System Name: Georgia Pacific CPLP Wauna		ID #: OR4190416					WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.09	0.06	0.04	0.04	0.03	0.03	0.09	
2	0.03	0.03	0.04	0.03	0.03	0.05	0.05	
3	0.03	0.03	0.03	0.02	0.02	0.03	0.03	
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
5	0.05	0.03	0.03	0.09	0.08	0.08	0.09	
6	0.04	0.05	0.04	0.03	0.03	0.03	0.05	
7	0.03	0.03	0.04	0.03	0.03	0.03	0.04	
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
9	0.03	0.04	0.02	0.02	0.03	0.03	0.04	
10	0.03	0.03	0.02	0.04	0.12	0.06	0.12	
11	0.07	0.10	0.11	0.10	0.14	0.18	0.18	
12	0.17	0.02	0.02	0.03	0.02	0.02	0.17	
13	0.03	0.03	0.02	0.03	0.02	0.03	0.03	
14	0.03	0.02	0.04	0.02	0.03	0.03	0.04	
15	0.03	0.03	0.03	0.05	0.04	0.07	0.07	
16	0.07	0.04	0.04	0.05	0.05	0.06	0.07	
17	0.08	0.08	0.07	0.05	0.05	0.07	0.08	
18	0.05	0.09	0.09	0.12	0.09	0.08	0.12	
19	0.07	0.09	0.07	0.07	0.04	0.08	0.09	
20	0.08	0.07	0.06	0.10	0.10	0.08	0.10	
21	0.07	0.07	0.04	0.03	0.04	0.03	0.07	
22	0.03	0.03	0.04	0.04	0.03	0.04	0.04	
23	0.03	0.03	0.04	0.04	0.06	0.06	0.06	
24	0.04	0.05	0.04	0.04	0.08	0.07	0.08	
25	0.06	0.05	0.07	0.04	0.04	0.04	0.07	
26	0.03	0.03	0.03	0.03	0.04	0.03	0.04	
27	0.03	0.03	0.03	0.02	0.01	0.02	0.03	
28	0.03	0.03	0.02	0.02	0.01	0.03	0.03	
29	0.01	0.02	0.02	0.02	0.02	0.04	0.04	
30	0.08	0.02	0.08	0.02	0.02	0.04	0.08	
31	0.02	0.02	0.02	0.02	0.02	0.03	0.03	

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE <sup>2</sup> triggers	YES		
Notes:		Printed Name: Terry Force	
		SIGNATURE: 	
		Phone# (503) 455-3331	CERT# 88783

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: TP - A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416

Month/Year: Jan - 21

Disinfection  
Giardia Log  
Inactiv: 1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.2	110	132.0	8.1	7.74	60.0	Yes	83
2	1	110	110.0	8.6	7.70	64.0	Yes	84
3	1	110	110.0	8.8	7.54	62.0	Yes	76
4	1	110	110.0	8.1	7.75	57.0	Yes	84
5	1	110	110.0	8.0	7.75	57.0	Yes	81
6	1	110	110.0	8.0	7.50	57.0	Yes	81
7	1	110	110.0	9.3	7.65	51.0	Yes	84
8	1	110	110.0	9.5	7.68	51.0	Yes	96
9	1	110	110.0	9.0	7.64	52.0	Yes	94
10	1	110	110.0	9.1	7.90	62.0	Yes	78
11	1	110	110.0	8.1	8.50	72.0	Yes	78
12	1	110	110.0	8.1	8.33	70.0	Yes	79
13	1	110	110.0	6.7	7.88	66.0	Yes	76
14	1	110	110.0	9.1	7.50	52.0	Yes	72
15	1	110	110.0	9.5	7.40	49.0	Yes	82
16	1	110	110.0	9.3	7.45	47.0	Yes	72
17	1	110	110.0	9.4	7.63	50.0	Yes	81
18	1	110	110.0	8.4	7.49	54.0	Yes	76
19	1	110	110.0	7.9	7.57	56.0	Yes	74
20	1	110	110.0	8.4	7.70	55.0	Yes	81
21	1	110	110.0	7.8	7.79	59.0	Yes	85
22	1	110	110.0	8.7	7.48	53.0	Yes	83
23	1	110	110.0	8.2	7.80	49.0	Yes	79
24	1	110	110.0	8.1	7.80	58.0	Yes	75
25	1	110	110.0	7.7	8.00	64.0	Yes	79
26	1	110	110.0	6.3	8.10	71.0	Yes	69
27	1	110	110.0	6.5	7.98	73.0	Yes	72
28	1	110	110.0	6.5	7.98	69.0	Yes	74
29	1	110	110.0	6.7	7.86	65.0	Yes	75
30	1	110	110.0	7.3	7.46	66.0	Yes	75
31	1	110	110.0	7.7	7.41	62.0	Yes	82

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX