

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: Clatsop

Conventional or Direct Filtration

Month/Year: Feb-21

System Name: Georgia Pacific CPLP Wauna		ID #: OR4190416					WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.02	0.02	0.04	0.02	0.02	0.02	0.04	
2	0.08	0.03	0.08	0.02	0.03	0.02	0.08	
3	0.02	0.02	0.04	0.03	0.04	0.02	0.04	
4	0.02	0.02	0.04	0.02	0.02	0.04	0.04	
5	0.02	0.02	0.02	0.04	0.02	0.02	0.04	
6	0.02	0.08	0.02	0.02	0.02	0.06	0.08	
7	0.02	0.02	0.05	0.02	0.03	0.02	0.05	
8	0.02	0.02	0.03	0.02	0.03	0.03	0.03	
9	0.02	0.02	0.03	0.05	0.06	0.06	0.06	
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
12	0.04	0.03	0.03	0.03	0.05	0.03	0.05	
13	0.03	0.03	0.03	0.04	0.03	0.03	0.04	
14	0.04	0.03	0.03	0.04	0.04	0.04	0.04	
15	0.05	0.04	0.04	0.06	0.04	0.06	0.06	
16	0.04	0.04	0.05	0.05	0.05	0.04	0.05	
17	0.04	0.04	0.04	0.06	0.05	0.04	0.06	
18	0.04	0.04	0.04	0.04	0.04	0.04	0.04	
19	0.06	0.04	0.04	0.04	0.05	0.04	0.06	
20	0.04	0.04	0.04	0.05	0.04	0.04	0.05	
21	0.04	0.04	0.04	0.04	0.06	0.08	0.08	
22	0.05	0.04	0.05	0.05	0.04	0.06	0.06	
23	0.04	0.06	0.05	0.02	0.02	0.02	0.06	
24	0.02	0.03	0.03	0.03	0.03	0.03	0.03	
25	0.02	0.03	0.03	0.03	0.03	0.03	0.03	
26	0.03	0.05	0.03	0.03	0.03	0.03	0.05	
27	0.03	0.04	0.03	0.04	0.06	0.04	0.06	
28	0.04	0.03	0.03	0.03	0.04	0.05	0.05	

Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES
All turbidity readings < IFE ² triggers	YES	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
		YES

Notes:	Printed Name: Terry Force
	SIGNATURE: 
	Phone# (503) 455-3331 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna	ID #: OR4190416	Month/Year: 02/21/21	Disinfection <i>Giardia</i> Log Inactiv:	1
---	-----------------	----------------------	--	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	yes / no	[GPM]
1	1	110	110.0	7.2	7.59	57.0	Yes	87
2	1	110	110.0	7.2	7.55	57.0	Yes	79
3	1	110	110.0	6.9	7.51	64.0	Yes	78
4	1	110	110.0	7.1	7.55	61.0	Yes	76
5	1	110	110.0	7.3	7.57	56.0	Yes	76
6	1	110	110.0	7.5	7.63	57.0	Yes	71
7	1	110	110.0	7.4	7.41	58.0	Yes	79
8	1	110	110.0	8.0	7.45	64.0	Yes	97
9	1	110	110.0	7.9	7.59	55.0	Yes	94
10	1	110	110.0	7.7	7.68	57.0	Yes	96
11	1	110	110.0	6.7	7.49	61.0	Yes	94
12	1	110	110.0	6.1	7.55	64.0	Yes	86
13	1	110	110.0	6.2	7.50	70.0	Yes	173
14	1	110	110.0	5.8	7.60	72.0	Yes	173
15	1	110	110.0	5.8	7.70	67.0	Yes	130
16	1	110	110.0	6.1	7.60	65.0	Yes	84
17	1	110	110.0	6.1	7.67	64.0	Yes	79
18	1	110	110.0	6.3	7.78	65.0	Yes	78
19	1	110	110.0	7.5	7.44	66.0	Yes	75
20	1	110	110.0	7.9	7.52	64.0	Yes	75
21	1	110	110.0	7.9	7.52	53.0	Yes	72
22	1	110	110.0	7.3	7.74	60.0	Yes	79
23	1	110	110.0	8.0	7.49	62.0	Yes	75
24	1	110	110.0	7.8	7.62	56.0	Yes	80
25	1	110	110.0	7.7	7.56	58.0	Yes	77
26	1	110	110.0	8.3	7.49	56.0	Yes	78
27	1	110	110.0	8.0	7.53	65.0	Yes	72
28	1	110	110.0	8.3	7.59	61.0	Yes	71

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 P/