


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop
 Month/ Year: Mar-21

Conventional or Direct Filtration

System Name:	Georgia Pacific CPLP Wauna		ID #: OR4190416				WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.04	0.04	0.04	0.04	0.06	0.04	0.06	
2	0.04	0.04	0.04	0.06	0.05	0.05	0.06	
3	0.04	0.05	0.05	0.06	0.05	0.05	0.06	
4	0.05	0.04	0.07	0.06	0.03	0.03	0.07	
5	0.03	0.03	0.05	0.04	0.04	0.04	0.05	
6	0.04	0.05	0.04	0.04	0.04	0.04	0.05	
7	0.04	0.04	0.30	0.08	0.04	0.04	0.30	
8	0.04	0.06	0.05	0.04	0.09	0.05	0.09	
9	0.04	0.05	0.04	0.05	0.09	0.12	0.12	
10	0.05	0.07	0.06	0.05	0.05	0.11	0.11	
11	0.05	0.05	0.18	0.06	0.06	0.06	0.18	
12	0.09	0.08	0.12	0.07	0.07	0.08	0.12	
13	0.07	0.03	0.03	0.04	0.04	0.04	0.07	
14	0.05	0.07	0.18	0.04	0.05	0.22	0.22	
15	0.08	0.05	0.09	0.04	0.04	0.06	0.09	
16	0.04	0.04	0.06	0.06	0.06	0.05	0.06	
17	0.05	0.05	0.05	0.05	0.06	0.21	0.21	
18	0.05	0.06	0.06	0.06	0.06	0.22	0.22	
19	0.11	0.07	0.08	0.06	0.05	0.05	0.11	
20	0.05	0.07	0.06	0.07	0.09	0.07	0.09	
21	0.07	0.07	0.07	0.07	0.07	0.08	0.08	
22	0.07	0.07	0.08	0.07	0.07	0.07	0.08	
23	0.08	0.08	0.08	0.11	0.08	0.08	0.11	
24	0.09	0.09	0.09	0.08	0.09	0.09	0.09	
25	0.09	0.09	0.09	0.09	0.09	0.09	0.09	
26	0.10	0.09	0.11	0.02	0.05	0.02	0.11	
27	0.06	0.08	0.04	0.02	0.02	0.02	0.08	
28	0.04	0.04	0.05	0.05	0.06	0.02	0.06	
29	0.03	0.02	0.02	0.02	0.02	0.04	0.04	
30	0.02	0.04	0.02	0.02	0.03	0.03	0.04	
31	0.08	0.05	0.16	0.03	0.03	0.03	0.16	

		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		
Notes:	Printed Name: Terry Force		
	SIGNATURE: 		
	Phone# (503) 455-3331		88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	Georgia Pacific CPLP Wauna	ID #: OR4190416	Month/Year:	03/01/21	Disinfection Giardia Log Inactiv:	1
---------------------	----------------------------	------------------------	--------------------	----------	------------------------------------------	---

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	7.6	7.59	56.0	Yes	75
2	1.00	110	110.0	7.2	7.90	64.0	Yes	73
3	1.00	110	110.0	8.3	7.62	61.0	Yes	78
4	1.00	110	110.0	6.6	7.61	58.0	Yes	74
5	1.00	110	110.0	8.2	7.67	55.0	Yes	79
6	1.00	110	110.0	8.5	7.67	54.0	Yes	72
7	1.00	110	110.0	8.8	7.54	61.0	Yes	75
8	1.00	110	110.0	9.0	7.54	67.0	Yes	74
9	1.00	110	110.0	8.8	7.94	58.0	Yes	76
10	1.00	110	110.0	7.6	8.00	65.0	Yes	84
11	1.00	110	110.0	8.7	7.60	60.0	Yes	85
12	1.00	110	110.0	8.5	7.43	56.0	Yes	81
13	1.00	110	110.0	8.7	7.65	53.0	yes	79
14	1.00	110	110.0	8.7	7.65	52.0	yes	75
15	1.00	110	110.0	9.4	7.61	63.0	Yes	79
16	1.00	110	110.0	8.8	7.44	59.0	Yes	79
17	1.00	110	110.0	8.3	7.77	57.0	yes	77
18	1.00	110	110.0	8.1	7.75	57.0	yes	78
19	1.00	110	110.0	9.6	7.62	57.0	yes	78
20	1.00	110	110.0	9.5	7.56	54.0	yes	79
21	1.00	110	110.0	9.3	7.56	52.0	yes	95
22	1.00	110	110.0	9.3	7.55	49.0	yes	84
23	1.00	110	110.0	9.5	7.55	51.0	Yes	82
24	1.00	110	110.0	8.7	7.40	50.0	Yes	75
25	1.00	110	110.0	8.7	7.52	50.0	Yes	76
26	1.00	110	110.0	9.0	7.56	50.0	Yes	76
27	1.00	110	110.0	9.3	7.48	52.0	yes	71
28	1.00	110	110.0	9.8	7.51	51.0	yes	75
29	1.00	110	110.0	9.9	7.47	51.0	yes	82
30	1.00	110	110.0	9.5	7.53	52.0	yes	78
31	1.00	110	110.0	10.3	7.62	51.0	Yes	82

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours

Revised October 2016-8 PAX