


OHA - Drinking Water Services -Turbidity Monitoring Report Form Conventional or Direct Filtration							County:	Clatsop
							Month/Year:	Apr-21
System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.03	0.04	0.03	0.04	0.03	0.04	0.04	
2	0.03	0.03	0.06	0.03	0.03	0.04	0.06	
3	0.04	0.04	0.06	0.04	0.04	0.04	0.06	
4	0.07	0.04	0.04	0.04	0.04	0.04	0.07	
5	0.04	0.04	0.04	0.04	0.04	0.04	0.04	
6	0.04	0.05	0.04	0.04	0.06	0.05	0.06	
7	0.05	0.05	0.05	0.06	0.05	0.05	0.06	
8	0.05	0.05	0.04	0.05	0.07	0.05	0.07	
9	0.05	0.05	0.06	0.05	0.06	0.06	0.06	
10	0.06	0.07	0.06	0.08	0.08	0.08	0.08	
11	0.21	0.05	0.05	0.05	0.05	0.06	0.21	
12	0.07	0.06	0.12	0.08	0.06	0.08	0.12	
13	0.08	0.08	0.06	0.07	0.09	0.09	0.09	
14	0.08	0.08	0.09	0.10	0.10	0.11	0.11	
15	0.09	0.11	0.08	0.08	0.08	0.08	0.11	
16	0.09	0.09	0.11	0.03	0.03	0.03	0.11	
17	0.03	0.03	0.03	0.03	0.07	0.05	0.07	
18	0.10	0.07	0.08	0.08	0.10	0.10	0.10	
19	0.10	0.10	0.06	0.08	0.06	0.10	0.10	
20	0.10	0.10	0.12	0.12	0.11	0.12	0.12	
21	0.12	0.12	0.13	0.12	0.04	0.03	0.13	
22	0.03	0.03	0.10	0.09	0.05	0.05	0.10	
23	0.03	0.05	0.02	0.03	0.08	0.03	0.08	
24	0.03	0.03	0.04	0.10	0.03	0.03	0.10	
25	0.03	0.03	0.06	0.06	0.04	0.08	0.08	
26	0.05	0.06	0.05	0.05	0.06	0.05	0.06	
27	0.05	0.05	0.05	0.06	0.05	0.06	0.06	
28	0.06	0.06	0.06	0.05	0.16	0.04	0.16	
29	0.04	0.05	0.04	0.04	0.04	0.04	0.05	
30	0.04	0.04	0.04	0.04	0.04	0.05	0.05	

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:	Printed Name: Terry Force	
	SIGNATURE: 	
	Phone# (503) 455-3331	CERT# 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416							WTP - : A	
							Month/Year:	Apr-21
							Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ₃	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	10.4	7.70	51.0	Yes	81
2	1.00	110	110.0	9.8	7.70	50.0	Yes	74
3	1.00	110	110.0	9.6	7.73	51.0	Yes	72
4	1.00	110	110.0	11.0	7.55	49.0	Yes	81
5	1.00	110	110.0	11.3	7.55	46.0	Yes	89
6	1.00	110	110.0	11.3	7.80	47.0	Yes	81
7	1.00	110	110.0	11.1	7.69	46.0	Yes	85
8	1.00	110	110.0	10.0	7.70	48.0	Yes	72
9	1.00	110	110.0	10.0	7.70	49.0	Yes	74
10	1.00	110	110.0	10.0	7.70	49.0	Yes	80
11	1.00	110	110.0	10.2	7.79	50.0	Yes	82
12	1.00	110	110.0	10.3	7.80	50.0	Yes	86
13	1.00	110	110.0	11.8	7.66	48.0	Yes	82
14	1.00	110	110.0	11.3	7.80	47.0	Yes	81
15	1.00	110	110.0	11.6	7.90	48.0	Yes	113
16	1.00	110	110.0	11.6	7.80	46.0	Yes	89
17	1.00	110	110.0	13.5	7.55	41.0	yes	78
18	1.00	110	110.0	13.4	7.50	40.0	Yes	83
19	1.00	110	110.0	13.6	7.59	40.0	Yes	89
20	1.00	110	110.0	14.4	7.62	39.0	Yes	82
21	1.00	110	110.0	14.6	7.54	39.0	Yes	83
22	1.00	110	110.0	14.3	7.55	35.0	Yes	79
23	1.00	110	110.0	13.8	7.63	37.0	Yes	85
24	1.00	110	110.0	12.8	7.43	39.0	Yes	77
25	1.00	110	110.0	12.7	7.44	39.0	Yes	78
26	1.00	110	110.0	12.7	7.51	38.0	Yes	80
27	1.00	110	110.0	12.5	7.48	38.0	Yes	90
28	1.00	110	110.0	13.0	7.50	38.0	Yes	84
29	1.00	110	110.0	14.4	7.45	41.0	Yes	81
30	1.00	110	110.0	13.0	7.53	38.0	Yes	77

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX