


OHA - Drinking Water Services -Turbidity Monitoring Report Form							County:	Clatsop
Conventional or Direct Filtration							Month/Year:	May-21
System Name: Georgia Pacific CPLP Wauna			ID #: OR4190416				WTP : TP -	A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.05	0.04	0.05	0.04	0.04	0.04	0.05	
2	0.04	0.04	0.04	0.04	0.04	0.04	0.04	
3	0.04	0.04	0.09	0.04	0.04	0.05	0.09	
4	0.05	0.08	0.05	0.05	0.06	0.09	0.09	
5	0.08	0.09	0.09	0.07	0.08	0.16	0.16	
6	0.13	0.10	0.10	0.02	0.03	0.03	0.13	
7	0.03	0.02	0.03	0.07	0.03	0.02	0.07	
8	0.02	0.02	0.02	0.02	0.04	0.03	0.04	
9	0.02	0.02	0.03	0.02	0.02	0.03	0.03	
10	0.03	0.02	0.04	0.03	0.03	0.03	0.04	
11	0.03	0.03	0.04	0.04	0.04	0.06	0.06	
12	0.07	0.07	0.05	0.06	0.03	0.05	0.07	
13	0.03	0.02	0.04	0.03	0.07	0.04	0.07	
14	0.04	0.06	0.05	0.09	0.04	0.06	0.09	
15	0.09	0.10	0.06	0.06	0.06	0.06	0.10	
16	0.08	0.08	0.09	0.08	0.08	0.09	0.09	
17	0.09	0.07	0.07	0.07	0.07	0.07	0.09	
18	0.08	0.09	0.09	0.09	0.09	0.09	0.09	
19	0.09	0.09	0.10	0.12	0.10	0.10	0.12	
20	0.10	0.10	0.11	0.14	0.04	0.04	0.14	
21	0.04	0.04	0.04	0.04	0.05	0.04	0.05	
22	0.04	0.04	0.04	0.05	0.05	0.17	0.17	
23	0.08	0.05	0.05	0.05	0.05	0.05	0.08	
24	0.05	0.06	0.09	0.07	0.10	0.07	0.10	
25	0.06	0.06	0.07	0.08	0.10	0.10	0.10	
26	0.07	0.07	0.07	0.07	0.07	0.08	0.08	
27	0.09	0.10	0.12	0.14	0.11	0.10	0.14	
28	0.11	0.16	0.13	0.04	0.05	0.13	0.16	
29	0.10	0.13	0.07	0.05	0.05	0.05	0.13	
30	0.06	0.09	0.07	0.06	0.05	0.05	0.09	
31	0.06	0.10	0.06	0.06	0.06	0.06	0.10	

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:	Printed Name: Terry Force
	SIGNATURE: 
	Phone# (503) 455-3231

CERT# 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	
System Name:	Georgia Pacific CPLP Wauna		ID #: OR4190416		Month/Year:	05/21/21	Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	13.4	7.53	37.0	YES	78
2	1.00	110	110.0	13.6	7.52	36.0	YES	75
3	1.00	110	110.0	13.9	7.55	36.0	YES	82
4	1.00	110	110.0	14.2	7.59	36.0	YES	82
5	1.00	110	110.0	14.0	7.54	36.0	YES	83
6	1.00	110	110.0	15.0	7.54	36.0	YES	83
7	1.00	110	110.0	15.0	7.49	36.0	YES	79
8	1.00	110	110.0	14.0	7.70	38.0	YES	80
9	1.00	110	110.0	14.9	7.72	36.0	YES	79
10	1.00	110	110.0	15.3	7.58	37.0	YES	91
11	1.00	110	110.0	15.9	7.61	38.0	YES	89
12	1.00	110	110.0	15.8	7.54	36.0	YES	90
13	1.00	110	110.0	16.0	7.56	36.0	YES	90
14	1.00	110	110.0	16.0	7.52	34.0	YES	87
15	1.00	110	110.0	16.8	7.60	34.0	YES	87
16	1.00	110	110.0	15.8	7.80	35.0	YES	89
17	1.00	110	110.0	16.5	7.73	32.0	YES	87
18	1.00	110	110.0	16.0	7.35	33.0	YES	85
19	1.00	110	110.0	15.6	7.39	31.0	YES	87
20	1.00	110	110.0	15.6	7.70	34.0	YES	94
21	1.00	110	110.0	16.1	7.50	31.0	YES	95
22	1.00	110	110.0	15.1	7.48	29.0	YES	82
23	1.00	110	110.0	15.2	7.43	28.0	YES	87
24	1.00	110	110.0	14.9	7.69	36.0	YES	92
25	1.00	110	110.0	15.2	7.50	32.0	YES	92
26	1.00	110	110.0	15.8	7.29	32.0	YES	133
27	1.00	110	110.0	15.3	7.31	32.0	YES	107
28	1.00	110	110.0	15.3	7.52	32.0	YES	86
29	1.00	110	110.0	15.4	7.52	32.0	YES	85
30	1.00	110	110.0	16.0	7.50	31.0	YES	86
31	1.00	110	110.0	16.4	7.52	30.0	YES	97

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX