

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration


Month/Year: Jun-21

System Name:		Georgia Pacific CPLP Wauna				ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]		
1	0.06	0.06	0.06	0.06	0.08	0.07	0.08		
2	0.06	0.10	0.06	0.08	0.08	0.08	0.10		
3	0.08	0.08	0.11	0.10	0.08	0.08	0.11		
4	0.08	0.09	0.09	0.09	0.09	0.09	0.09		
5	0.09	0.09	0.10	0.10	0.06	0.06	0.10		
6	0.06	0.06	0.08	0.06	0.09	0.06	0.09		
7	0.06	0.06	0.06	0.06	0.07	0.07	0.07		
8	0.07	0.07	0.07	0.08	0.08	0.07	0.08		
9	0.07	0.07	0.07	0.08	0.08	0.08	0.08		
10	0.08	0.08	0.08	0.08	0.08	0.08	0.08		
11	0.09	0.09	0.09	0.09	0.09	0.09	0.09		
12	0.08	0.09	0.09	0.10	0.10	0.09	0.10		
13	0.09	0.09	0.09	0.09	0.09	0.09	0.09		
14	0.09	0.09	0.09	0.09	0.10	0.10	0.10		
15	0.10	0.10	0.10	0.07	0.07	0.07	0.10		
16	0.08	0.08	0.08	0.07	0.07	0.07	0.08		
17	0.07	0.07	0.07	0.07	0.07	0.07	0.07		
18	0.07	0.07	0.09	0.08	0.08	0.08	0.09		
19	0.08	0.08	0.08	0.08	0.08	0.08	0.08		
20	0.08	0.08	0.08	0.08	0.08	0.08	0.08		
21	0.08	0.09	0.08	0.08	0.08	0.10	0.10		
22	0.09	0.09	0.09	0.09	0.09	0.09	0.09		
23	0.09	0.09	0.09	0.09	0.09	0.09	0.09		
24	0.09	0.10	0.10	0.08	0.09	0.08	0.10		
25	0.08	0.08	0.08	0.07	0.08	0.07	0.08		
26	0.08	0.07	0.08	0.07	0.08	0.08	0.08		
27	0.08	0.08	0.08	0.08	0.08	0.09	0.09		
28	0.08	0.08	0.08	0.08	0.08	0.09	0.09		
29	0.09	0.09	0.09	0.09	0.10	0.10	0.10		
30	0.14	0.11	0.10	0.10	0.11	0.11	0.14		

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE <sup>2</sup> triggers	YES		

Notes:

Printed Name: Terry Force

SIGNATURE: 

Phone# (503) 455-3331

88783

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Jun-21							Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	17.0	7.48	29.0	yes	112
2	1.00	110	110.0	17.9	7.56	28.0	yes	103
3	1.00	110	110.0	18.4	7.46	29.0	yes	100
4	1.00	110	110.0	18.6	7.47	28.0	yes	95
5	1.00	110	110.0	18.3	7.59	27.0	yes	81
6	1.00	110	110.0	17.2	7.69	30.0	yes	76
7	1.00	110	110.0	17.4	7.48	31.0	yes	95
8	1.00	110	110.0	17.4	7.60	28.0	yes	87
9	1.00	110	110.0	17.1	7.66	29.0	yes	91
10	1.00	110	110.0	17.4	7.58	32.0	yes	85
11	1.00	110	110.0	16.9	7.64	31.0	yes	85
12	1.00	110	110.0	17.6	7.63	31.0	yes	92
13	1.00	110	110.0	17.0	7.68	31.0	yes	98
14	1.00	110	110.0	16.9	7.57	30.0	yes	91
15	1.00	110	110.0	18.0	7.54	29.0	yes	84
16	1.00	110	110.0	18.1	7.70	29.0	yes	95
17	1.00	110	110.0	17.8	7.69	29.0	yes	106
18	1.00	110	110.0	18.0	7.55	27.0	yes	105
19	1.00	110	110.0	19.4	7.36	29.0	yes	91
20	1.00	110	110.0	19.9	7.48	28.0	yes	105
21	1.00	110	110.0	18.9	7.70	27.0	yes	106
22	1.00	110	110.0	19.0	7.65	27.0	yes	102
23	1.00	110	110.0	20.0	7.53	26.0	yes	95
24	1.00	110	110.0	20.4	7.57	28.0	yes	108
25	1.00	110	110.0	19.9	7.75	26.0	yes	96
26	1.00	110	110.0	20.0	7.80	26.0	yes	120
27	1.00	110	110.0	22.2	7.70	26.0	yes	137
28	1.00	110	110.0	21.1	7.67	23.0	yes	141
29	1.00	110	110.0	8.3	7.68	55.0	yes	130
30	1.00	110	110.0	21.6	7.69	23.0	yes	112

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX