

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: Clatsop

Conventional or Direct Filtration

Month/Year: Jul-21

System Name:		Georgia Pacific CPLP Wauna				ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]		
1	0.11	0.11	0.11	0.11	0.12	0.12	0.12		
2	0.12	0.12	0.13	0.14	0.14	0.09	0.14		
3	0.09	0.09	0.09	0.09	0.09	0.09	0.09		
4	0.09	0.09	0.09	0.09	0.09	0.10	0.10		
5	0.10	0.09	0.09	0.09	0.09	0.09	0.10		
6	0.09	0.09	0.10	0.10	0.10	0.10	0.10		
7	0.10	0.10	0.11	0.12	0.12	0.12	0.12		
8	0.13	0.13	0.14	0.12	0.12	0.13	0.14		
9	0.13	0.14	0.14	0.14	0.02	0.02	0.14		
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
11	0.02	0.03	0.02	0.02	0.02	0.02	0.03		
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
13	0.02	0.02	0.03	0.02	0.03	0.03	0.03		
14	0.02	0.02	0.03	0.03	0.03	0.03	0.03		
15	0.03	0.03	0.03	0.04	0.03	0.03	0.04		
16	0.03	0.05	0.03	0.03	0.03	0.03	0.05		
17	0.03	0.03	0.04	0.04	0.04	0.04	0.04		
18	0.04	0.04	0.04	0.04	0.06	0.04	0.06		
19	0.04	0.04	0.04	0.04	0.04	0.04	0.04		
20	0.05	0.07	0.05	0.05	0.05	0.07	0.07		
21	0.05	0.05	0.05	0.05	0.06	0.06	0.06		
22	0.05	0.06	0.06	0.06	0.06	0.06	0.06		
23	0.06	0.06	0.06	0.06	0.06	0.06	0.06		
24	0.08	0.07	0.07	0.07	0.07	0.07	0.08		
25	0.07	0.08	0.08	0.08	0.08	0.06	0.08		
26	0.06	0.09	0.07	0.07	0.07	0.08	0.09		
27	0.06	0.08	0.08	0.08	0.02	0.02	0.08		
28	0.02	0.01	0.02	0.02	0.02	0.02	0.02		
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
30	0.05	0.03	0.02	0.02	0.03	0.03	0.05		
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03		

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	yes	yes	yes
All turbidity readings < IFE <sup>2</sup> triggers	yes		

Notes:	Printed Name: Terry Force
	SIGNATURE: 
	Phone# (503) 455-3331 88783

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416	Month/ Year:	Jun-21	Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	21.7	7.48	23.0	yes	108
2	1.00	110	110.0	21.7	7.47	22.0	yes	108
3	1.00	110	110.0	21.2	7.50	22.0	yes	116
4	1.00	110	110.0	20.9	7.63	23.0	yes	110
5	1.00	110	110.0	21.5	7.43	23.0	yes	113
6	1.00	110	110.0	22.0	7.55	23.0	yes	121
7	1.00	110	110.0	21.3	7.75	24.0	yes	116
8	1.00	110	110.0	20.9	7.63	23.0	yes	115
9	1.00	110	110.0	22.9	7.38	23.0	yes	119
10	1.00	110	110.0	21.8	7.41	21.0	yes	111
11	1.00	110	110.0	22.4	7.44	21.0	yes	113
12	1.00	110	110.0	21.9	7.43	20.0	yes	111
13	1.00	110	110.0	21.7	7.50	21.0	yes	109
14	1.00	110	110.0	21.7	7.75	22.0	yes	107
15	1.00	110	110.0	21.3	7.61	24.0	yes	103
16	1.00	110	110.0	22.1	7.66	23.0	yes	108
17	1.00	110	110.0	21.9	7.44	22.0	yes	102
18	1.00	110	110.0	21.7	7.59	22.0	yes	113
19	1.00	110	110.0	21.6	7.55	22.0	yes	119
20	1.00	110	110.0	21.2	7.64	23.0	yes	116
21	1.00	110	110.0	22.1	7.44	23.0	yes	117
22	1.00	110	110.0	22.0	7.24	22.0	yes	113
23	1.00	110	110.0	22.2	7.55	21.0	yes	117
24	1.00	110	110.0	22.1	7.60	21.0	yes	123
25	1.00	110	110.0	22.0	7.50	21.0	yes	122
26	1.00	110	110.0	23.0	7.63	21.0	yes	119
27	1.00	110	110.0	22.7	7.58	20.0	yes	113
28	1.00	141	141.0	22.6	7.63	21.0	yes	195
29	1.00	110	110.0	23.3	7.50	21.0	yes	129
30	1.00	110	110.0	23.4	7.69	21.0	yes	127
31	1.00	110	110.0	22.7	7.68	21.0	yes	118

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX