

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clatsop**
 Month/Year: **Aug-21**

System Name: **Georgia Pacific CPLP Wauna** ID #: **OR4190416** WTP : TP - **A**

Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.04	0.04	0.04
2	0.04	0.04	0.04	0.04	0.04	0.04	0.04
3	0.04	0.04	0.04	0.04	0.05	0.05	0.05
4	0.05	0.05	0.05	0.06	0.06	0.06	0.06
5	0.06	0.06	0.07	0.08	0.08	0.08	0.08
6	0.09	0.09	0.12	0.12	0.13	0.13	0.13
7	0.14	0.14	0.13	0.14	0.14	0.15	0.15
8	0.08	0.06	0.07	0.07	0.07	0.07	0.08
9	0.08	0.08	0.08	0.08	0.08	0.08	0.08
10	0.08	0.08	0.08	0.09	0.06	0.06	0.09
11	0.07	0.07	0.07	0.07	0.07	0.07	0.07
12	0.07	0.08	0.08	0.08	0.04	0.04	0.08
13	0.04	0.05	0.04	0.04	0.04	0.05	0.05
14	0.05	0.04	0.04	0.05	0.05	0.05	0.05
15	0.05	0.05	0.05	0.05	0.08	0.06	0.08
16	0.06	0.06	0.06	0.06	0.07	0.07	0.07
17	0.07	0.07	0.07	0.05	0.05	0.05	0.07
18	0.05	0.05	0.05	0.05	0.05	0.05	0.05
19	0.05	0.05	0.05	0.05	0.05	0.06	0.06
20	0.06	0.06	0.06	0.06	0.06	0.06	0.06
21	0.06	0.06	0.06	0.06	0.07	0.07	0.07
22	0.07	0.07	0.07	0.07	0.07	0.07	0.07
23	0.08	0.08	0.08	0.06	0.06	0.06	0.08
24	0.06	0.06	0.06	0.07	0.07	0.07	0.07
25	0.07	0.07	0.06	0.07	0.07	0.07	0.07
26	0.07	0.07	0.08	0.08	0.08	0.04	0.08
27	0.04	0.04	0.04	0.04	0.04	0.04	0.04
28	0.04	0.04	0.04	0.04	0.04	0.05	0.05
29	0.05	0.05	0.08	0.08	0.08	0.08	0.08
30	0.08	0.09	0.09	0.02	0.02	0.02	0.09
31	0.02	0.02	0.03	0.03	0.04	0.04	0.04

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:

Name: Stephanie Vanderweide
Signature: *Stephanie Vanderweide*
Phone# (316) 259-1718 **882011**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna

ID #: OR4190416

Month/Year: 08/21

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ₃	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	110	110.0	23.0	7.55	22.0	yes	102
2	1	110	110.0	23.0	7.52	21.0	yes	119
3	1	110	110.0	23.1	7.49	20.0	yes	126
4	1	110	110.0	22.4	7.73	24.0	yes	129
5	1	110	110.0	22.5	8.03	24.0	yes	127
6	1	110	110.0	22.8	7.67	21.0	yes	119
7	1	110	110.0	22.7	7.86	22.0	yes	116
8	1	110	110.0	22.5	7.88	23.0	yes	110
9	1	110	110.0	22.4	7.80	22.0	yes	117
10	1	110	110.0	23.3	7.43	22.0	yes	130
11	1	110	110.0	22.9	7.67	21.0	yes	139
12	1	110	110.0	23.2	7.67	20.0	yes	131
13	1	110	110.0	23.3	7.67	20.0	yes	128
14	1	110	110.0	23.7	7.55	21.0	yes	123
15	1	110	110.0	23.4	7.53	21.0	yes	126
16	1	110	110.0	22.8	7.65	21.0	yes	117
17	1	110	110.0	22.8	7.68	21.0	yes	101
18	1	110	110.0	22.9	7.64	21.0	yes	111
19	1	110	110.0	22.7	7.50	21.0	yes	104
20	1	110	110.0	22.1	7.63	22.0	yes	96
21	1	110	110.0	22.1	7.64	22.0	yes	94
22	1	110	110.0	21.7	7.72	22.0	yes	96
23	1	110	110.0	21.4	7.80	24.0	yes	82
24	1	110	110.0	22.0	7.81	25.0	yes	109
25	1	110	110.0	21.1	7.79	25.0	yes	99
26	1	110	110.0	20.9	7.76	25.0	yes	100
27	1	110	110.0	21.0	7.80	25.0	yes	97
28	1	110	110.0	20.7	7.80	25.0	yes	102
29	1	110	110.0	21.4	7.80	24.0	yes	99
30	1	110	110.0	20.9	7.54	25.0	yes	90
31	1	110	110.0	20.5	7.51	24.0	yes	115

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 P/