

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Sep-21

System Name:	Georgia Pacific CPLP Wauna						ID #: OR4190416	WTP : TP - A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.04	0.04	0.04	0.04	0.04	0.04	0.04	
2	0.05	0.07	0.03	0.03	0.05	0.03	0.07	
3	0.03	0.04	0.04	0.04	0.04	0.04	0.04	
4	0.04	0.04	0.04	0.04	0.05	0.05	0.05	
5	0.05	0.06	0.06	0.06	0.06	0.07	0.07	
6	0.05	0.05	0.06	0.06	0.06	0.07	0.07	
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
8	0.02	0.02	0.02	0.02	0.03	0.02	0.03	
9	0.02	0.02	0.02	0.03	0.03	0.03	0.03	
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
11	0.03	0.03	0.04	0.04	0.04	0.03	0.04	
12	0.03	0.03	0.04	0.04	0.04	0.02	0.04	
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
14	0.03	0.02	0.02	0.02	0.02	0.02	0.03	
15	0.02	0.02	0.02	0.02	0.02	0.03	0.03	
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
17	0.03	0.03	0.03	0.03	0.03	0.04	0.04	
18	0.04	0.04	0.04	0.04	0.04	0.04	0.04	
19	0.04	0.04	0.05	0.05	0.05	0.05	0.05	
20	0.02	0.03	0.03	0.03	0.03	0.03	0.03	
21	0.03	0.03	0.03	0.02	0.02	0.02	0.03	
22	0.02	0.03	0.03	0.02	0.02	0.03	0.03	
23	0.03	0.04	0.02	0.01	0.01	0.01	0.04	
24	0.01	0.02	0.01	0.02	0.02	0.01	0.02	
25	0.01	0.01	0.02	0.02	0.02	0.02	0.02	
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
27	0.02	0.02	0.02	0.04	0.02	0.02	0.04	
28	0.02	0.02	0.02	0.02	0.02	0.03	0.03	
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
31							0.00	

		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes:

Printed Name: Terry Force

SIGNATURE: *Terry Force*

Phone# (503) 455-3331 | 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Sep-21							Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	20.0	7.71	25.0	yes	86
2	1.00	110	110.0	20.4	7.83	26.0	yes	102
3	1.00	110	110.0	20.6	7.81	25.0	yes	107
4	1.00	110	110.0	20.5	7.73	25.0	yes	109
5	1.00	110	110.0	20.5	7.75	25.0	yes	109
6	1.00	110	110.0	20.5	7.73	25.0	yes	102
7	1.00	110	110.0	21.3	7.65	25.0	yes	115
8	1.00	110	110.0	21.5	7.68	24.0	yes	123
9	1.00	110	110.0	20.9	7.75	24.0	yes	111
10	1.00	110	110.0	20.9	7.71	21.0	yes	101
11	1.00	110	110.0	20.7	7.65	24.0	yes	109
12	1.00	110	110.0	21.0	7.58	24.0	yes	106
13	1.00	110	110.0	20.7	7.77	25.0	yes	106
14	1.00	110	110.0	21.1	7.79	24.0	yes	98
15	1.00	110	110.0	20.3	7.65	25.0	yes	106
16	1.00	110	110.0	20.5	7.65	26.0	yes	97
17	1.00	110	110.0	20.0	7.65	25.0	yes	94
18	1.00	110	110.0	19.6	7.61	25.0	yes	87
19	1.00	110	110.0	19.9	7.52	26.0	yes	88
20	1.00	110	110.0	20.0	7.54	25.0	yes	94
21	1.00	110	110.0	19.1	7.62	26.0	yes	105
22	1.00	110	110.0	19.3	7.62	26.0	yes	109
23	1.00	110	110.0	19.7	7.55	27.0	yes	131
24	1.00	110	110.0	20.0	7.62	27.0	yes	122
25	1.00	110	110.0	20.0	7.66	25.0	yes	105
26	1.00	110	110.0	19.2	7.69	27.0	yes	94
27	1.00	110	110.0	18.9	7.71	27.0	yes	93
28	1.00	110	110.0	18.4	7.72	28.0	yes	95
29	1.00	110	110.0	18.5	7.71	28.0	yes	111
30	1.00	110	110.0	18.5	7.67	28.0	yes	96
31			0.0				no	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX