


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Oct-21

System Name:		Georgia Pacific CPLP Wauna				ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]		
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
2	0.03	0.03	0.03	0.03	0.04	0.04	0.04		
3	0.04	0.04	0.04	0.04	0.04	0.04	0.04		
4	0.04	0.04	0.04	0.05	0.02	0.02	0.05		
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
6	0.02	0.02	0.02	0.02	0.02	0.03	0.03		
7	0.02	0.02	0.02	0.02	0.02	0.03	0.03		
8	0.03	0.03	0.03	0.02	0.03	0.03	0.03		
9	0.03	0.04	0.03	0.03	0.03	0.04	0.04		
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
11	0.03	0.04	0.03	0.03	0.03	0.03	0.04		
12	0.03	0.03	0.04	0.04	0.04	0.04	0.04		
13	0.04	0.04	0.04	0.04	0.04	0.04	0.04		
14	0.04	0.04	0.04	0.04	0.04	0.04	0.04		
15	0.04	0.04	0.05	0.05	0.04	0.05	0.05		
16	0.04	0.04	0.05	0.05	0.05	0.05	0.05		
17	0.05	0.05	0.05	0.05	0.05	0.05	0.05		
18	0.05	0.05	0.05	0.05	0.05	0.06	0.06		
19	0.06	0.05	0.06	0.06	0.06	0.06	0.06		
20	0.06	0.06	0.06	0.06	0.06	0.06	0.06		
21	0.06	0.06	0.06	0.06	0.06	0.06	0.06		
22	0.06	0.07	0.07	0.07	0.07	0.07	0.07		
23	0.07	0.07	0.07	0.07	0.07	0.07	0.07		
24	0.07	0.07	0.07	0.07	0.07	0.07	0.07		
25	0.08	0.08	0.08	0.02	0.03	0.03	0.08		
26	0.02	0.03	0.03	0.03	0.03	0.03	0.03		
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
28	0.03	0.03	0.30	0.03	0.03	0.03	0.30		
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
30	0.03	0.03	0.03	0.03	0.03	0.04	0.04		
31	0.03	0.03	0.03	0.03	0.03	0.04	0.04		
					Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings ≤ 0.3 NTU?		Yes		CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?			
All 4-hour turbidity readings ≤ 1 NTU?		Yes		Yes		Yes			
All turbidity readings < IFE ² triggers		Yes							
Notes:				Printed Name: Terry Force					
				SIGNATURE: 					
				Phone# (503) 455-3331		88783			

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	
System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416	Month/ Year:	Oct-21	Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	18.6	7.5	28.0	yes	94
2	1.00	110	110.0	18.8	7.5	27.0	yes	96
3	1.00	110	110.0	18.2	7.6	27.0	yes	91
4	1.00	110	110.0	17.7	7.6	29.0	yes	93
5	1.00	110	110.0	17.8	7.5	28.0	yes	86
6	1.00	110	110.0	17.8	7.4	28.0	yes	86
7	1.00	110	110.0	17.8	7.6	28.0	yes	83
8	1.00	110	110.0	17.1	7.6	30.0	yes	93
9	1.00	110	110.0	17.8	7.6	30.0	yes	95
10	1.00	110	110.0	16.8	7.6	31.0	yes	77
11	1.00	110	110.0	17.0	7.7	32.0	yes	85
12	1.00	110	110.0	16.2	7.7	33.0	yes	91
13	1.00	110	110.0	16.1	7.7	34.0	yes	88
14	1.00	110	110.0	16.2	7.7	33.0	yes	86
15	1.00	110	110.0	16.4	7.8	34.0	yes	78
16	1.00	110	110.0	16.5	7.8	34.0	yes	78
17	1.00	110	110.0	16.0	7.7	34.0	yes	77
18	1.00	110	110.0	15.8	7.8	35.0	yes	73
19	1.00	110	110.0	15.4	7.8	36.0	yes	77
20	1.00	110	110.0	15.4	7.8	36.0	yes	76
21	1.00	110	110.0	15.3	7.8	36.0	yes	74
22	1.00	110	110.0	15.0	7.7	36.0	yes	77
23	1.00	110	110.0	15.0	7.8	36.0	yes	70
24	1.00	110	110.0	15.0	7.7	35.0	yes	70
25	1.00	110	110.0	14.7	7.7	36.0	yes	79
26	1.00	110	110.0	14.4	7.7	37.0	yes	70
27	1.00	110	110.0	14.2	7.7	37.0	yes	72
28	1.00	110	141.0	14.3	7.8	38.0	yes	81
29	1.00	110	110.0	14.9	7.4	36.0	yes	83
30	1.00	110	110.0	14.2	7.5	35.0	yes	77
31	1.00	110	110.0	13.7	7.6	36.0	yes	80

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX