

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: Clatsop

Conventional or Direct Filtration

Month/Year: Dec-21

System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.02	0.02	0.02	0.03	0.03	0.02	0.03	
2	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
7	0.02	0.02	0.02	0.02	0.02	0.03	0.03	
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
12	0.02	0.02	0.03	0.02	0.02	0.02	0.03	
13	0.02	0.02	0.03	0.02	0.02	0.02	0.03	
14	0.02	0.04	0.02	0.02	0.02	0.02	0.04	
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
17	0.02	0.03	0.02	0.02	0.02	0.02	0.03	
18	0.03	0.03	0.02	0.02	0.03	0.03	0.03	
19	0.02	0.02	0.02	0.02	0.02	0.03	0.03	
20	0.02	0.02	0.02	0.02	0.02	0.03	0.03	
21	0.02	0.02	0.03	0.03	0.10	0.02	0.10	
22	0.02	0.03	0.03	0.02	0.02	0.07	0.07	
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
24	0.02	0.02	0.03	0.02	0.02	0.03	0.03	
25	0.03	0.03	0.02	0.03	0.03	0.02	0.03	
26	0.03	0.02	0.02	0.02	0.04	0.03	0.04	
27	0.03	0.10	0.03	0.05	0.06	0.06	0.10	
28	0.23	0.05	0.02	0.02	0.03	0.03	0.23	
29	0.02	0.03	0.02	0.03	0.02	0.02	0.03	
30	0.03	0.03	0.03	0.02	0.02	0.02	0.03	
31	0.03	0.02	0.02	0.02	0.03	0.05	0.05	

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE <sup>2</sup> triggers	Yes		

Notes:	Printed Name: Terry Force
	SIGNATURE: 
	Phone# (503) 455-3331   88783

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Indivd. Filter Effl. (333-061-0040(1)(d)(B&C))



OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Dec-21							WTP - : A	
							Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	11.1	7.62	45.0	yes	81
2	1.00	110	110.0	11.3	7.62	44.0	yes	70
3	1.00	110	110.0	11.3	7.61	44.0	yes	70
4	1.00	110	110.0	10.6	7.64	46.0	yes	85
5	1.00	110	110.0	10.6	7.55	48.0	yes	72
6	1.00	110	110.0	10.0	7.63	48.0	yes	74
7	1.00	110	110.0	10.0	7.66	49.0	yes	83
8	1.00	110	110.0	10.1	7.65	48.0	yes	83
9	1.00	110	110.0	9.6	7.68	50.0	yes	81
10	1.00	110	110.0	9.4	7.68	51.0	yes	80
11	1.00	110	110.0	9.5	7.73	52.0	yes	80
12	1.00	110	110.0	8.9	7.51	52.0	yes	75
13	1.00	110	110.0	8.9	7.52	50.0	yes	71
14	1.00	110	110.0	8.8	7.63	52.0	yes	74
15	1.00	110	110.0	8.8	7.65	53.0	yes	79
16	1.00	110	110.0	8.4	7.61	53.0	yes	81
17	1.00	110	110.0	8.5	7.61	53.0	yes	83
18	1.00	110	110.0	8.7	7.56	51.0	yes	71
19	1.00	110	110.0	8.4	7.56	52.0	yes	90
20	1.00	110	110.0	8.2	7.53	52.0	yes	84
21	1.00	110	110.0	8.1	7.48	52.0	yes	82
22	1.00	110	110.0	8.1	7.50	52.0	yes	81
23	1.00	110	110.0	8.2	7.57	53.0	yes	82
24	1.00	110	110.0	7.9	7.56	54.0	yes	78
25	1.00	110	935.0	7.8	7.50	53.0	yes	87
26	1.00	110	110.0	7.5	7.37	54.0	yes	110
27	1.00	110	110.0	7.0	7.53	57.0	yes	133
28	1.00	110	110.0	7.0	7.39	56.0	yes	159
29	1.00	110	110.0	6.5	7.38	58.0	yes	162
30	1.00	110	110.0	6.5	7.64	61.0	yes	154
31	1.00	110	110.0	6.1	7.64	63.0	yes	115

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX