

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Jan-22

System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.02	0.02	0.02	0.03	0.03	0.02	0.03	
2	0.02	0.02	0.03	0.02	0.02	0.02	0.03	
3	0.03	0.03	0.03	0.03	0.03	0.04	0.04	
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
5	0.03	0.02	0.02	0.02	0.02	0.02	0.03	
6	0.02	0.03	0.02	0.02	0.03	0.20	0.20	
7	0.02	0.03	0.03	0.05	0.06	0.05	0.06	
8	0.02	0.02	0.03	0.03	0.03	0.03	0.03	
9	0.10	0.04	0.07	0.04	0.03	0.03	0.10	
10	0.03	0.03	0.04	0.03	0.02	0.05	0.05	
11	0.04	0.03	0.03	0.04	0.03	0.04	0.04	
12	0.03	0.03	0.07	0.04	0.03	0.04	0.07	
13	0.05	0.02	0.03	0.02	0.02	0.02	0.05	
14	0.02	0.03	0.02	0.03	0.03	0.03	0.03	
15	0.03	0.03	0.03	0.02	0.02	0.03	0.03	
16	0.03	0.03	0.02	0.03	0.03	0.03	0.03	
17	0.03	0.03	0.03	0.04	0.05	0.04	0.05	
18	0.03	0.03	0.05	0.03	0.03	0.02	0.05	
19	0.02	0.02	0.02	0.02	0.03	0.02	0.03	
20	0.02	0.03	0.03	0.03	0.03	0.03	0.03	
21	0.03	0.02	0.02	0.01	0.01	0.01	0.03	
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
25	0.03	0.02	0.02	0.02	0.03	0.02	0.03	
26	0.01	0.01	0.02	0.02	0.02	0.01	0.02	
27	0.02	0.02	0.02	0.02	0.07	0.02	0.07	
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
30	0.02	0.02	0.03	0.02	0.02	0.02	0.03	
31	0.02	0.02	0.02	0.02	0.03	0.03	0.03	

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE <sup>2</sup> triggers	Yes		

Notes:	Printed Name: Terry Force
	SIGNATURE: <i>Terry Force</i>
	Phone# (503) 455-3331 88783

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP -: A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416	Month/ Year:	Jan-22	Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	5.6	7.62	65.0	yes	120
2	1.00	110	110.0	5.4	7.82	70.0	yes	123
3	1.00	110	110.0	5.9	7.77	71.0	yes	116
4	1.00	110	110.0	5.9	7.70	69.0	yes	106
5	1.00	110	110.0	5.5	7.69	67.0	yes	113
6	1.00	110	110.0	6.3	7.47	70.0	yes	104
7	1.00	110	110.0	6.2	7.53	60.0	yes	103
8	1.00	110	110.0	6.4	7.52	59.0	yes	104
9	1.00	110	110.0	6.5	7.67	62.0	yes	105
10	1.00	110	110.0	7.1	7.71	60.0	yes	116
11	1.00	110	110.0	7.3	7.63	58.0	yes	105
12	1.00	110	110.0	8.1	7.71	56.0	yes	99
13	1.00	110	110.0	7.1	7.65	73.0	yes	102
14	1.00	110	110.0	7.1	7.55	62.0	yes	96
15	1.00	110	110.0	6.7	7.74	63.0	yes	97
16	1.00	110	110.0	6.8	7.72	65.0	yes	95
17	1.00	110	110.0	6.8	7.79	67.0	yes	95
18	1.00	110	110.0	6.8	7.75	67.0	yes	100
19	1.00	110	110.0	6.7	7.89	71.0	yes	99
20	1.00	110	110.0	7.5	8.00	68.0	yes	99
21	1.00	110	110.0	6.7	7.38	54.0	yes	94
22	1.00	110	110.0	6.9	7.33	55.0	yes	95
23	1.00	110	110.0	6.7	7.71	55.0	yes	98
24	1.00	110	110.0	6.2	7.65	56.0	yes	91
25	1.00	110	110.0	6.5	7.77	66.0	yes	94
26	1.00	110	110.0	6.2	7.87	71.0	yes	91
27	1.00	110	110.0	6.0	7.78	69.0	yes	98
28	1.00	110	110.0	6.7	7.78	66.0	yes	105
29	1.00	110	110.0	5.9	7.52	58.0	yes	89
30	1.00	110	110.0	5.4	7.59	58.0	yes	88
31	1.00	110	110.0	5.3	7.61	58.0	yes	92

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX