

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: Clatsop

Conventional or Direct Filtration

Month/Year: Feb-22

System Name:		Georgia Pacific CPLP Wauna				ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]		
1	0.02	0.02	0.03	0.03	0.03	0.03	0.03		
2	0.02	0.02	0.03	0.03	0.03	0.02	0.03		
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
8	0.03	0.02	0.02	0.02	0.02	0.02	0.03		
9	0.03	0.02	0.02	0.02	0.02	0.02	0.03		
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
11	0.02	0.02	0.02	0.03	0.03	0.02	0.03		
12	0.02	0.03	0.02	0.02	0.03	0.02	0.03		
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
16	0.02	0.04	0.02	0.02	0.02	0.02	0.04		
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
18	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
21	0.03	0.02	0.02	0.02	0.02	0.02	0.03		
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
25	0.02	0.02	0.02	0.02	0.03	0.02	0.03		
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
29							0.00		
30							0.00		
31							0.00		

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	Yes	Yes
All turbidity readings < IFE ² triggers	YES		

Notes:	Printed Name: Terry Force
	SIGNATURE: 
	Phone# (503) 455-3331 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Feb-22							Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	5.2	7.68	60.0	yes	93
2	1.00	110	110.0	5.4	7.72	71.0	yes	92
3	1.00	110	110.0	5.4	7.63	69.0	yes	95
4	1.00	110	110.0	5.7	7.62	57.0	yes	88
5	1.00	110	110.0	5.8	7.74	69.0	yes	89
6	1.00	110	110.0	5.6	7.75	70.0	yes	84
7	1.00	110	110.0	5.6	7.76	71.0	yes	92
8	1.00	110	110.0	5.7	7.77	60.0	yes	94
9	1.00	110	110.0	6.0	7.79	59.0	yes	95
10	1.00	110	110.0	6.5	7.78	67.0	yes	91
11	1.00	110	110.0	6.2	7.85	70.0	yes	94
12	1.00	110	110.0	6.3	7.72	66.0	yes	120
13	1.00	110	110.0	7.4	7.69	60.0	yes	89
14	1.00	110	110.0	6.5	7.57	56.0	yes	90
15	1.00	110	110.0	6.5	7.60	56.0	yes	89
16	1.00	110	110.0	6.4	7.70	56.0	yes	91
17	1.00	110	110.0	6.4	7.84	59.0	yes	90
18	1.00	110	110.0	6.1	7.78	69.0	yes	94
19	1.00	110	110.0	6.5	7.79	68.0	yes	92
20	1.00	110	110.0	6.5	7.85	69.0	yes	88
21	1.00	110	110.0	7.5	7.68	59.0	yes	86
22	1.00	110	110.0	6.2	7.71	58.0	yes	84
23	1.00	110	110.0	5.9	7.70	59.0	yes	100
24	1.00	110	110.0	5.7	7.79	72.0	yes	105
25	1.00	110	110.0	5.3	7.79	74.0	yes	94
26	1.00	110	110.0	5.4	7.64	59.0	yes	95
27	1.00	110	110.0	5.2	7.68	60.0	yes	101
28	1.00	110	141.0	5.8	7.67	58.0	yes	92
29			0.0				no	
30			0.0				no	
31			0.0				no	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX