

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: Clatsop

Conventional or Direct Filtration

Month/Year: Mar-22

System Name:		Georgia Pacific CPLP Wauna					ID #: OR4190416	WTP : TP - A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.02	0.02	0.02	0.02	0.04	0.02	0.04	
2	0.02	0.02	0.02	0.02	0.02	0.03	0.03	
3	0.03	0.03	0.03	0.03	0.04	0.05	0.05	
4	0.03	0.03	0.03	0.03	0.03	0.04	0.04	
5	0.04	0.04	0.03	0.04	0.03	0.03	0.04	
6	0.03	0.04	0.03	0.03	0.02	0.02	0.04	
7	0.02	0.06	0.02	0.03	0.02	0.02	0.06	
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
13	0.03	0.02	0.03	0.02	0.03	0.02	0.03	
14	0.03	0.03	0.02	0.04	0.02	0.02	0.04	
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
18	0.02	0.02	0.03	0.02	0.02	0.02	0.03	
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
21	0.02	0.03	0.02	0.02	0.02	0.02	0.03	
22	0.03	0.02	0.02	0.02	0.02	0.02	0.03	
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
25	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
31	0.02	0.02	0.02	0.02	0.02	0.02	0.02	

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:	Printed Name: Terry Force
	SIGNATURE: 
	Phone# (503) 455-3331 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416		Month/ Year:		Mar-22		Disinfection Giardia Log Inactiv:		1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow					
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]					
1	1.00	110	110.0	6.5	7.67	55.0	yes	94					
2	1.00	110	110.0	7.0	7.47	50.0	yes	90					
3	1.00	110	110.0	7.0	7.50	53.0	yes	192					
4	1.00	110	110.0	7.1	7.90	58.0	yes	85					
5	1.00	110	110.0	7.1	7.90	57.0	yes	85					
6	1.00	110	110.0	7.5	7.61	58.0	yes	86					
7	1.00	110	110.0	7.6	7.74	62.0	yes	199					
8	1.00	110	110.0	7.4	7.40	50.0	yes	89					
9	1.00	110	110.0	8.2	7.78	61.0	yes	78					
10	1.00	110	110.0	7.7	7.24	64.0	yes	78					
11	1.00	110	110.0	7.6	7.75	67.0	yes	78					
12	1.00	110	110.0	7.2	7.82	66.0	yes	78					
13	1.00	110	110.0	7.3	7.52	59.0	yes	86					
14	1.00	110	110.0	7.5	7.57	60.0	yes	82					
15	1.00	110	110.0	7.5	7.71	60.0	yes	88					
16	1.00	110	110.0	7.7	7.60	57.0	yes	88					
17	1.00	110	110.0	8.7	7.57	53.0	yes	84					
18	1.00	110	110.0	8.4	7.48	65.0	yes	84					
19	1.00	110	110.0	8.6	7.55	48.0	yes	84					
20	1.00	110	110.0	8.2	7.62	48.0	yes	89					
21	1.00	110	110.0	8.1	7.62	49.0	yes	85					
22	1.00	110	110.0	8.3	7.59	47.0	yes	87					
23	1.00	110	110.0	9.0	7.80	49.0	yes	90					
24	1.00	110	110.0	8.6	7.86	51.0	yes	89					
25	1.00	110	110.0	9.1	7.86	49.0	yes	88					
26	1.00	110	110.0	9.8	7.60	47.0	yes	80					
27	1.00	110	110.0	10.3	7.50	43.0	yes	81					
28	1.00	110	110.0	9.8	7.74	45.0	yes	95					
29	1.00	110	110.0	9.8	7.74	45.0	yes	108					
30	1.00	110	110.0	10.0	7.57	48.0	yes	94					
31	1.00	110	110.0	10.0	7.63	50.0	yes	90					

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX