

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Apr-22

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 WTP : TP - A

Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02
2	0.02	0.04	0.02	0.02	0.02	0.02	0.04
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02
7	0.02	0.02	0.03	0.02	0.02	0.02	0.03
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02
11	0.02	0.02	0.02	0.03	0.02	0.02	0.03
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02
13	0.02	0.02	0.02	0.02	0.03	0.02	0.03
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02
15	0.03	0.02	0.02	0.03	0.03	0.02	0.03
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02
18	0.02	0.02	0.02	0.02	0.02	0.04	0.04
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02
21	0.02	0.03	0.02	0.02	0.02	0.02	0.03
22	0.02	0.02	0.02	0.02	0.02	0.03	0.03
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02
25	0.02	0.02	0.02	0.02	0.03	0.02	0.03
26	0.02	0.03	0.02	0.02	0.03	0.02	0.03
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:

Printed Name: Terry Force

SIGNATURE: 

Phone# (503) 455-3331

88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Indivld. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Apr-22							WTP -: A	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	Disinfection Giardia Log Inactiv:	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	10.0	7.63	50.0	yes	84
2	1.00	110	110.0	10.7	7.63	47.0	yes	75
3	1.00	110	110.0	10.7	7.56	48.0	yes	77
4	1.00	110	110.0	10.3	7.37	48.0	yes	85
5	1.00	110	110.0	10.6	7.41	50.0	yes	88
6	1.00	110	110.0	10.9	7.36	52.0	yes	79
7	1.00	110	110.0	10.7	7.71	48.0	yes	94
8	1.00	110	110.0	11.0	7.67	49.0	yes	78
9	1.00	110	110.0	10.8	7.48	48.0	yes	72
10	1.00	110	110.0	10.2	7.57	46.0	yes	73
11	1.00	110	110.0	10.1	7.57	44.0	yes	72
12	1.00	110	110.0	9.8	7.40	44.0	yes	77
13	1.00	110	110.0	9.4	7.72	46.0	yes	75
14	1.00	110	110.0	9.3	7.72	46.0	yes	80
15	1.00	110	110.0	9.1	7.55	51.0	yes	83
16	1.00	110	110.0	9.2	7.56	44.0	yes	72
17	1.00	110	110.0	9.5	7.71	46.0	yes	75
18	1.00	110	110.0	10.8	7.72	49.0	yes	77
19	1.00	110	110.0	10.2	7.60	45.0	yes	80
20	1.00	110	110.0	10.2	7.36	43.0	yes	81
21	1.00	110	110.0	10.0	7.47	41.0	yes	89
22	1.00	110	110.0	10.1	7.53	41.0	yes	80
23	1.00	110	110.0	10.5	7.59	47.0	yes	83
24	1.00	110	110.0	12.3	7.60	48.0	yes	78
25	1.00	110	110.0	11.9	7.64	44.0	yes	77
26	1.00	110	110.0	11.7	7.64	44.0	yes	80
27	1.00	110	110.0	11.5	7.48	40.0	yes	72
28	1.00	110	110.0	11.6	7.72	40.0	yes	72
29	1.00	110	110.0	11.3	7.79	42.0	yes	74
30	1.00	110	110.0	11.5	7.65	39.0	yes	72

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX