

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: Clatsop

Conventional or Direct Filtration

Month/Year: May-22

System Name:		Georgia Pacific CPLP Wauna				ID #: OR4190416	WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
2	0.02	0.02	0.01	0.01	0.02	0.02	0.02	
3	0.02	0.01	0.01	0.01	0.02	0.02	0.02	
4	0.02	0.01	0.01	0.01	0.02	0.02	0.02	
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
11	0.02	0.02	0.02	0.02	0.05	0.02	0.05	
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
13	0.02	0.03	0.02	0.03	0.02	0.02	0.03	
14	0.02	0.03	0.02	0.02	0.02	0.02	0.03	
15	0.02	0.02	0.02	0.02	0.03	0.02	0.03	
16	0.02	0.03	0.02	0.03	0.03	0.02	0.03	
17	0.02	0.03	0.03	0.02	0.02	0.02	0.03	
18	0.02	0.02	0.01	0.02	0.02	0.02	0.02	
19	0.01	0.01	0.01	0.01	0.02	0.02	0.02	
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
21	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
25	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
27	0.02	0.02	0.03	0.02	0.03	0.02	0.03	
28	0.02	0.02	0.02	0.03	0.02	0.02	0.03	
29	0.02	0.03	0.04	0.03	0.02	0.02	0.04	
30	0.03	0.02	0.02	0.04	0.03	0.02	0.04	
31	0.02	0.03	0.04	0.04	0.02	0.02	0.04	

		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:	Printed Name: Terry Force
	SIGNATURE: 
	Phone# (503) 455-3331 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: May-22							WTP -: A	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	Disinfection Giardia Log Inactiv:	1
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	CT Met? ³	Peak Hourly Demand Flow
							Yes / No	[GPM]
1	1.00	110	110.0	11.5	7.65	45.0	yes	75
2	1.00	110	110.0	11.9	7.72	45.0	yes	89
3	1.00	110	110.0	11.9	7.83	47.0	yes	77
4	1.00	110	110.0	11.9	7.83	47.0	yes	88
5	1.00	110	110.0	12.2	7.65	38.0	yes	72
6	1.00	110	110.0	12.3	7.61	38.0	yes	71
7	1.00	110	110.0	12.3	7.66	37.0	yes	71
8	1.00	110	110.0	12.4	7.50	38.0	yes	64
9	1.00	110	110.0	13.3	7.62	38.0	yes	76
10	1.00	110	110.0	13.2	7.46	39.0	yes	101
11	1.00	110	110.0	12.5	7.62	36.0	yes	104
12	1.00	110	110.0	11.9	7.46	36.0	yes	136
13	1.00	110	110.0	12.1	7.52	38.0	yes	88
14	1.00	110	110.0	13.1	7.42	37.0	yes	88
15	1.00	110	110.0	13.1	7.58	34.0	yes	88
16	1.00	110	110.0	12.9	7.55	34.0	yes	102
17	1.00	110	110.0	14.7	7.49	36.0	yes	96
18	1.00	110	110.0	12.7	7.60	35.0	yes	94
19	1.00	110	110.0	12.8	7.61	35.0	yes	90
20	1.00	110	110.0	13.8	7.62	33.0	yes	90
21	1.00	110	110.0	13.1	7.59	40.0	yes	100
22	1.00	110	110.0	13.7	7.76	41.0	yes	99
23	1.00	110	110.0	14.7	7.79	33.0	yes	100
24	1.00	110	110.0	14.3	7.67	33.0	yes	109
25	1.00	110	110.0	15.4	7.44	33.0	yes	114
26	1.00	110	110.0	15.8	7.54	33.0	yes	110
27	1.00	110	110.0	15.2	7.62	30.0	yes	108
28	1.00	110	141.0	14.2	7.67	38.0	yes	86
29	1.00	110	110.0	13.8	7.60	38.0	yes	90
30	1.00	110	110.0	13.9	7.56	37.0	yes	85
31	1.00	110	110.0	14.1	7.67	37.0	yes	95

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.