

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Clatsop**  
 Month/Year: **Jun-22**

Conventional or Direct Filtration


System Name: **Georgia Pacific CPLP Wauna** ID #: **OR4190416** WTP : **TP - A**

Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02
2	0.02	0.02	0.02	0.02	0.03	0.02	0.03
3	0.02	0.02	0.06	0.02	0.02	0.02	0.06
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02
5	0.02	0.02	0.02	0.02	0.02	0.03	0.03
6	0.02	0.03	0.02	0.02	0.03	0.03	0.03
7	0.02	0.02	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.04	0.04	0.03	0.04
10	0.03	0.03	0.04	0.04	0.02	0.02	0.04
11	0.02	0.02	0.03	0.02	0.02	0.02	0.03
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02
13	0.02	0.02	0.02	0.02	0.02	0.03	0.03
14	0.02	0.02	0.02	0.02	0.05	0.02	0.05
15	0.02	0.02	0.03	0.03	0.02	0.02	0.03
16	0.02	0.02	0.02	0.05	0.02	0.02	0.05
17	0.02	0.02	0.02	0.02	0.06	0.02	0.06
18	0.02	0.02	0.02	0.03	0.02	0.02	0.03
19	0.02	0.02	0.02	0.02	0.03	0.02	0.03
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02
21	0.02	0.02	0.02	0.02	0.02	0.02	0.02
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02
24	0.03	0.02	0.02	0.03	0.03	0.02	0.03
25	0.02	0.02	0.02	0.02	0.02	0.02	0.02
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02
27	0.02	0.02	0.02	0.05	0.04	0.02	0.05
28	0.02	0.02	0.02	0.02	0.03	0.02	0.03
29	0.02	0.02	0.02	0.02	0.03	0.05	0.05
30	0.02	0.02	0.02	0.02	0.02	0.03	0.03
31							0.00

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE <sup>2</sup> triggers	YES		

Notes:

Printed Name: **Terry Force**

SIGNATURE: 

Phone# (503) 455-3331 88783

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416	Month/ Year:	Jun-22	Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	14.9	7.66	35.0	yes	97
2	1.00	110	110.0	15.0	7.70	40.0	yes	95
3	1.00	110	110.0	15.7	7.57	34.0	yes	82
4	1.00	110	110.0	15.0	7.58	34.0	yes	84
5	1.00	110	110.0	15.3	7.66	35.0	yes	82
6	1.00	110	110.0	15.5	7.66	34.0	yes	85
7	1.00	110	110.0	14.9	7.59	34.0	yes	102
8	1.00	110	110.0	15.3	7.60	33.0	yes	96
9	1.00	110	110.0	15.6	7.62	33.0	yes	95
10	1.00	110	110.0	16.1	7.51	35.0	yes	95
11	1.00	110	110.0	15.9	7.62	32.0	yes	91
12	1.00	110	110.0	15.6	7.62	33.0	yes	93
13	1.00	110	110.0	15.0	7.68	35.0	yes	89
14	1.00	110	110.0	14.7	7.63	35.0	yes	90
15	1.00	110	110.0	14.6	7.52	33.0	yes	85
16	1.00	110	110.0	14.6	7.55	34.0	yes	81
17	1.00	110	110.0	14.6	7.57	35.0	yes	82
18	1.00	110	110.0	15.5	7.50	36.0	yes	81
19	1.00	110	110.0	14.9	7.53	33.0	yes	84
20	1.00	110	110.0	14.4	7.63	36.0	yes	90
21	1.00	110	110.0	15.3	7.65	34.0	yes	89
22	1.00	110	110.0	16.0	7.66	33.0	yes	91
23	1.00	110	110.0	15.6	7.73	34.0	yes	97
24	1.00	110	110.0	15.8	7.65	33.0	yes	132
25	1.00	110	110.0	16.6	7.59	32.0	yes	107
26	1.00	110	110.0	17.2	7.66	31.0	yes	133
27	1.00	110	110.0	17.4	7.66	30.0	yes	123
28	1.00	110	141.0	17.3	7.75	32.0	yes	86
29	1.00	110	110.0	17.3	7.75	32.0	yes	96
30	1.00	110	110.0	17.2	7.74	33.0	yes	97

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX