

OHA - Drinking Water Services - Turbidity Monitoring Report Form


County: Clatsop

Conventional or Direct Filtration

Month/Year: Jul-22

System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.03	0.03	0.02	0.02	0.02	0.02	0.03	
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
4	0.03	0.03	0.04	0.03	0.02	0.02	0.04	
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
11	0.02	0.02	0.02	0.03	0.03	0.03	0.03	
12	0.03	0.03	0.03	0.03	0.02	0.02	0.03	
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
17	0.02	0.02	0.02	0.02	0.02	0.03	0.03	
18	0.03	0.02	0.03	0.02	0.02	0.02	0.03	
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
21	0.02	0.02	0.02	0.02	0.03	0.02	0.03	
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
23	0.02	0.02	0.02	0.02	0.02	0.03	0.03	
24	0.03	0.02	0.02	0.02	0.02	0.02	0.03	
25	0.02	0.02	0.02	0.02	0.04	0.04	0.04	
26	0.02	0.02	0.02	0.03	0.02	0.02	0.03	
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
28	0.02	0.02	0.04	0.02	0.02	0.02	0.04	
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
30	0.02	0.02	0.03	0.03	0.03	0.05	0.05	
31	0.02	0.02	0.03	0.02	0.03	0.03	0.03	

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:	Printed Name: Terry Force
	SIGNATURE: 
	Phone# (503) 455-3331 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Jul-22							Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	17.9	7.72	26.0	yes	88
2	1.00	110	110.0	17.9	7.70	30.0	yes	90
3	1.00	110	110.0	17.9	7.67	30.0	yes	83
4	1.00	110	110.0	19.7	7.73	30.0	yes	88
5	1.00	110	110.0	19.0	7.58	28.0	yes	89
6	1.00	110	110.0	18.7	7.77	28.0	yes	97
7	1.00	110	110.0	18.7	7.70	28.0	yes	108
8	1.00	110	110.0	18.5	7.65	28.0	yes	108
9	1.00	110	110.0	18.6	7.69	28.0	yes	108
10	1.00	110	110.0	18.9	7.72	24.0	yes	101
11	1.00	110	110.0	19.4	7.66	23.0	yes	113
12	1.00	110	110.0	20.2	7.69	23.0	yes	120
13	1.00	110	110.0	20.2	7.57	26.0	yes	107
14	1.00	110	110.0	19.8	7.75	26.0	yes	109
15	1.00	110	110.0	20.0	7.76	26.0	yes	109
16	1.00	110	110.0	20.3	7.71	25.0	yes	113
17	1.00	110	110.0	19.8	7.73	26.0	yes	101
18	1.00	110	110.0	19.9	7.74	26.0	yes	106
19	1.00	110	110.0	19.8	7.73	26.0	yes	105
20	1.00	110	110.0	21.0	7.35	25.0	yes	120
21	1.00	110	110.0	20.8	7.58	23.0	yes	106
22	1.00	110	110.0	20.5	7.58	24.0	yes	102
23	1.00	110	110.0	20.3	7.68	26.0	yes	98
24	1.00	110	110.0	20.5	7.67	22.0	yes	119
25	1.00	110	110.0	20.9	7.69	21.0	yes	131
26	1.00	110	110.0	21.1	7.68	21.0	yes	131
27	1.00	110	110.0	21.1	7.68	21.0	yes	121
28	1.00	110	110.0	22.8	7.59	23.0	yes	121
29	1.00	110	110.0	23.0	7.78	23.0	yes	126
30	1.00	110	110.0	22.2	7.78	23.0	yes	134
31	1.00	110	110.0	22.5	7.77	22.0	yes	125

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX