


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop  
 Month/Year: Aug-22

Conventional or Direct Filtration

System Name:		Georgia Pacific CPLP Wauna				ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]		
1	0.03	0.02	0.02	0.02	0.03	0.02	0.03		
2	0.02	0.02	0.02	0.03	0.06	0.02	0.06		
3	0.02	0.03	0.03	0.03	0.03	0.03	0.03		
4	0.03	0.04	0.03	0.03	0.03	0.03	0.04		
5	0.03	0.04	0.05	0.04	0.07	0.02	0.07		
6	0.02	0.02	0.02	0.03	0.03	0.02	0.03		
7	0.02	0.02	0.03	0.02	0.02	0.02	0.03		
8	0.03	0.02	0.02	0.02	0.02	0.02	0.03		
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
11	0.03	0.03	0.03	0.02	0.02	0.02	0.03		
12	0.02	0.02	0.02	0.02	0.04	0.02	0.04		
13	0.02	0.02	0.02	0.02	0.03	0.03	0.03		
14	0.03	0.03	0.04	0.03	0.02	0.02	0.04		
15	0.02	0.02	0.02	0.02	0.02	0.03	0.03		
16	0.03	0.02	0.02	0.02	0.03	0.03	0.03		
17	0.03	0.02	0.02	0.02	0.02	0.03	0.03		
18	0.03	0.02	0.02	0.02	0.03	0.02	0.03		
19	0.02	0.03	0.03	0.03	0.04	0.03	0.04		
20	0.03	0.04	0.04	0.04	0.04	0.04	0.04		
21	0.04	0.04	0.05	0.02	0.02	0.02	0.05		
22	0.02	0.02	0.03	0.02	0.02	0.02	0.03		
23	0.03	0.03	0.03	0.02	0.03	0.03	0.03		
24	0.03	0.02	0.02	0.02	0.02	0.03	0.03		
25	0.02	0.02	0.03	0.02	0.03	0.03	0.03		
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
27	0.04	0.03	0.03	0.03	0.04	0.03	0.04		
28	0.04	0.04	0.04	0.04	0.04	0.04	0.04		
29	0.04	0.04	0.05	0.03	0.03	0.03	0.05		
30	0.03	0.03	0.03	0.03	0.04	0.04	0.04		
31	0.04	0.04	0.04	0.04	0.04	0.05	0.05		

		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE <sup>2</sup> triggers	YES		
Notes:		Printed Name: Terry Force	
		SIGNATURE: 	
		Phone# (503) 455-3351	88783

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416	Month/ Year:	Aug-22	Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	23.4	7.73	21.0	yes	117
2	1.00	110	110.0	22.5	7.71	22.0	yes	111
3	1.00	110	110.0	22.8	7.77	22.0	yes	105
4	1.00	110	110.0	22.8	7.67	22.0	yes	104
5	1.00	110	110.0	22.8	7.62	22.0	yes	121
6	1.00	110	110.0	23.3	7.47	21.0	yes	118
7	1.00	110	110.0	22.3	7.61	21.0	yes	126
8	1.00	110	110.0	21.9	7.61	23.0	yes	112
9	1.00	110	110.0	22.1	7.66	19.0	yes	115
10	1.00	110	110.0	22.3	7.66	19.0	yes	106
11	1.00	110	110.0	21.7	7.72	20.0	yes	109
12	1.00	110	110.0	22.3	7.68	19.0	yes	104
13	1.00	110	110.0	22.0	7.56	19.0	yes	102
14	1.00	110	110.0	21.6	7.80	24.0	yes	114
15	1.00	110	110.0	22.2	7.88	24.0	yes	116
16	1.00	110	110.0	23.0	7.88	23.0	yes	119
17	1.00	110	110.0	22.4	7.81	23.0	yes	125
18	1.00	110	110.0	23.3	7.63	22.0	yes	129
19	1.00	110	110.0	23.3	7.73	21.0	yes	119
20	1.00	110	110.0	22.5	7.76	23.0	yes	106
21	1.00	110	110.0	23.2	7.63	22.0	yes	108
22	1.00	110	110.0	23.3	7.63	20.0	yes	116
23	1.00	110	110.0	22.5	7.69	21.0	yes	110
24	1.00	110	110.0	22.4	7.74	22.0	yes	118
25	1.00	110	110.0	22.7	7.71	22.0	yes	112
26	1.00	110	110.0	22.5	7.69	22.0	yes	105
27	1.00	110	110.0	22.1	7.69	22.0	yes	98
28	1.00	110	110.0	21.9	7.69	22.0	yes	122
29	1.00	110	110.0	24.4	7.69	22.0	yes	119
30	1.00	110	110.0	23.4	7.69	24.0	yes	125
31	1.00	110	110.0	22.8	7.70	22.0	yes	113

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX