

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop


Month/Year: Sep-22

Conventional or Direct Filtration

System Name:		Georgia Pacific CPLP Wauna					ID #: OR4190416	WTP : TP - A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.05	0.05	0.05	0.05	0.04	0.04	0.05	
2	0.04	0.04	0.04	0.02	0.02	0.02	0.04	
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
4	0.02	0.02	0.02	0.02	0.03	0.02	0.03	
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
9	0.02	0.03	0.02	0.02	0.02	0.02	0.03	
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
16	0.02	0.02	0.03	0.02	0.02	0.02	0.03	
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
18	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
22	0.02	0.02	0.02	0.15	0.50	0.24	0.50	
23	0.08	0.07	0.08	0.03	0.02	0.02	0.08	
24	0.12	0.04	0.03	0.09	0.09	0.13	0.13	
25	0.05	0.02	0.02	0.02	0.02	0.02	0.05	
26	0.02	0.02	0.02	0.01	0.02	0.02	0.02	
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02	

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	NO	NO
All turbidity readings < IFE <sup>2</sup> triggers	YES		

Notes: Potable water system was not in use on 9/20 and 9/21 for scheduled maintenance outage - please see cover letter for further explanation. Data for these days is recorded as "OFF".

Printed Name: Terry Force	
SIGNATURE: 	
Phone# (503) 455-3331	88783

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Sep-22						Disinfection Giardia Log Inactiv:		1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	22.6	7.69	23.0	yes	109
2	1.00	110	110.0	21.9	7.70	22.0	yes	97
3	1.00	110	110.0	21.6	7.68	23.0	yes	102
4	1.00	110	110.0	21.6	7.67	22.0	yes	95
5	1.00	110	110.0	21.8	7.69	22.0	yes	101
6	1.00	110	110.0	23.0	7.57	23.0	yes	112
7	1.00	110	110.0	22.1	7.59	20.0	yes	103
8	1.00	110	110.0	21.3	7.60	22.0	yes	98
9	1.00	110	110.0	21.3	7.61	22.0	yes	102
10	1.00	110	110.0	22.0	7.58	21.0	yes	103
11	1.00	110	110.0	21.2	7.67	23.0	yes	106
12	1.00	110	110.0	20.8	7.67	24.0	yes	94
13	1.00	110	110.0	20.8	7.67	24.0	yes	101
14	1.00	110	110.0	20.6	7.66	24.0	yes	103
15	1.00	110	110.0	20.3	7.66	25.0	yes	99
16	1.00	110	110.0	20.3	7.65	26.0	yes	119
17	1.00	110	110.0	20.8	7.69	26.0	yes	78
18	1.00	110	110.0	20.2	7.69	26.0	yes	94
19	1.00	110	110.0	20.6	7.77	26.0	yes	81
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	1.00	110	110.0	21.9	7.67	25.0	yes	59
23	1.00	110	110.0	20.4	7.57	23.0	yes	62
24	0.03	110	3.3	20.2	7.69	25.0	no	60
25	0.80	110	88.0	20.2	7.80	29.0	yes	66
26	1.20	110	135.0	20.0	7.80	28.0	yes	82
27	1.20	110	132.0	19.7	7.65	26.0	yes	59
28	1.00	110	110.0	19.4	7.65	26.0	yes	65
29	0.48	110	52.8	20.2	7.67	28.0	yes	67
30	1.12	110	123.2	20.2	7.55	25.0	yes	67

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX